THE PENNSYLVANIA STATE UNIVERSITY SCHREYER HONORS COLLEGE

DEPARTMENT OF ARCHITECTURAL ENGINEERING

ENERGY EFFICIENT LIGHTING AND ELECTRICAL SYSTEMS DESIGN FOR A HIGHRISE BUILDING WITH AN EXPLORATION OF THE URBAN IMPACT ON DAYLIGHTING

LARA NOELLE KAISERIAN SPRING 2014

A thesis submitted in partial fulfillment of the requirements for a baccalaureate degree in Architectural Engineering with honors in Architectural Engineering

Reviewed and approved* by the following:

Richard Mistrick Associate Professor of Architectural Engineering Thesis Supervisor Honors Adviser

Kevin Houser Professor of Architectural Engineering Thesis Reader

* Signatures on file in the Schreyer Honors College.

ABSTRACT

This report details the lighting and electrical design for a net-zero office highrise in San Francisco, CA. This is just one part of a team design that included the mechanical, structural, electrical, and lighting systems, as well as a construction engineering plan. The group worked together to create a cohesive design that prioritized energy efficiency, environmental considerations, and occupant comfort. Also, as San Francisco is in a seismic region, occupant safety in an earthquake situation was of paramount importance.

The project focuses on the lobby and a typical office floor, as well as whole-building systems design. The lighting and electrical design strove to increase efficiency and decrease total energy consumption, and this was achieved through the use of a number of different strategies. For lighting, these include daylighting, lighting controls, and task lighting. The electrical system uses a combination AC/DC distribution system, dual emergency electrical risers, natural gas-powered fuel cells, and a server room supporting virtual computing.

To offset the building's energy use, energy is generated via onsite and offsite solar arrays, as well as an onsite human waste-to-power converter. Through the combination of energy efficient design and energy generation techniques, the building achieves a net-zero annual energy consumption.

TABLE OF CONTENTS

List of Figuresv
List of Tablesviii
Acknowledgementsx
Chapter 1 Introduction1
Executive Summary1Team Direction: Goals and Attitude3Design Process4Code Analysis5
Chapter 2 Energy
Onsite Energy
Chapter 3 Daylighting12
Lobby Spatial Daylight Autonomy12Office Façade Design13Shading14Office Spatial Daylight Autonomy17Spatial Daylight Autonomy Calculations18
Chapter 4 Urban Daylighting Study21
Scope of Study21The Model22Surrounding Buildings24The Trials25The Results26Spatial Daylight Autonomy26Annual Direct Sun29Conclusions32
Chapter 5 Electric Lighting
Lighting Design Concept

Controls	42
Lobby	44
Office	47
Chapter 6 Electrical Design	52
AC/DC Distribution	
Mechanical	54
Lighting	55
Façade	
Source Fuel vs. Site Fuel	58
Fuel Cell	59
Server Room	61
Emergency Power System	62
Seismic Design	
Lobby Lighting	
Dual Electrical Risers	64
Plug Load Controls	66
Building Space Use Summary	70
Dunding Space Ose Summary	
Chapter 7 Fire Alarm Design	71
Chapter 8 Data/Telecommunications Design	74
Chapter 9 LEED	76
L	
Chapter 10 Conclusion	79
Appendix A Rejected Energy Generation Methods	82
Onsite Energy	82
Offsite Energy	
Offsite Lifergy	
Appendix B Onsite and Offsite Energy	85
Onsita Salar	85
Human Wester to Dower	0J 96
Officite Scher Amore	
Olisile Solar Afray	80
Appendix C Facade	90
Electrochromic Glass Cost Analysis	91
Appendix D Urban Daylighting Study	
Appendix E Lighting Design	
Luminaire Schedule	

Office Lighting Design Building Lighting Power Densities	104 106
Appendix F AC/DC Distribution	
Building Loads	111
Appendix G Fuel Cell	113
Appendix H Server Room Sizing	116
Appendix I Seismic Design	
Lobby Earthquake Analysis	120
BIBLIOGRAPHY	

iv

LIST OF FIGURES

Figure 1. AEVITAS Attitude with Goal Breakout	4
Figure 2. Solar Radiation Map with Context	7
Figure 3. Roof Solar Radiation Map	8
Figure 4. Supercritical Water Oxidation Schematic	9
Figure 5. Annual Solar Radiation Map of the United States	10
Figure 6. First Floor Lobby Circulation Spatial Daylight Autonomy	13
Figure 7. Second Floor Lobby Circulation Spatial Daylight Autonomy	13
Figure 8. Façade Design with Panel Removed	14
Figure 9. Façade Solar Radiation Maps	15
Figure 10. Renderings of Untinted and Tinted Electrochromic Glass	16
Figure 11. Open Office Daylight Autonomy	18
Figure 12. AutoCAD Office Floor Model	22
6	
Figure 13. 350 Mission Urban Context	24
Figure 13. 350 Mission Urban Context Figure 14. Spatial Daylight Autonomy Comparison – Floor 5	24 Error! Bookmark no
 Figure 13. 350 Mission Urban Context Figure 14. Spatial Daylight Autonomy Comparison – Floor 5 Figure 15. Spatial Daylight Autonomy Comparison – Floor 18 	24 Error! Bookmark no 26
 Figure 13. 350 Mission Urban Context Figure 14. Spatial Daylight Autonomy Comparison – Floor 5 Figure 15. Spatial Daylight Autonomy Comparison – Floor 18 Figure 16. Spatial Daylight Autonomy Comparison – Floor 30 	24 Error! Bookmark no 26 26
 Figure 13. 350 Mission Urban Context Figure 14. Spatial Daylight Autonomy Comparison – Floor 5 Figure 15. Spatial Daylight Autonomy Comparison – Floor 18 Figure 16. Spatial Daylight Autonomy Comparison – Floor 30 Figure 17. Spatial Daylight Autonomy Comparison – Northwest Façade 	24 Error! Bookmark no 26 26 28
 Figure 13. 350 Mission Urban Context Figure 14. Spatial Daylight Autonomy Comparison – Floor 5 Figure 15. Spatial Daylight Autonomy Comparison – Floor 18 Figure 16. Spatial Daylight Autonomy Comparison – Floor 30 Figure 17. Spatial Daylight Autonomy Comparison – Northwest Façade Figure 18. Spatial Daylight Autonomy Comparison – Northeast Façade 	24 Error! Bookmark no 26 26 28 28
 Figure 13. 350 Mission Urban Context Figure 14. Spatial Daylight Autonomy Comparison – Floor 5 Figure 15. Spatial Daylight Autonomy Comparison – Floor 18 Figure 16. Spatial Daylight Autonomy Comparison – Floor 30 Figure 17. Spatial Daylight Autonomy Comparison – Northwest Façade Figure 18. Spatial Daylight Autonomy Comparison – Northeast Façade Figure 19. Spatial Daylight Autonomy Comparison – Southwest Façade 	24 Error! Bookmark no 26 26 28 28 28
 Figure 13. 350 Mission Urban Context Figure 14. Spatial Daylight Autonomy Comparison – Floor 5 Figure 15. Spatial Daylight Autonomy Comparison – Floor 18 Figure 16. Spatial Daylight Autonomy Comparison – Floor 30 Figure 17. Spatial Daylight Autonomy Comparison – Northwest Façade Figure 18. Spatial Daylight Autonomy Comparison – Northeast Façade Figure 19. Spatial Daylight Autonomy Comparison – Southwest Façade Figure 20. Spatial Daylight Autonomy Comparison – Southeast Façade 	24 Error! Bookmark no 26 26 28 28 28 28
 Figure 13. 350 Mission Urban Context Figure 14. Spatial Daylight Autonomy Comparison – Floor 5 Figure 15. Spatial Daylight Autonomy Comparison – Floor 18 Figure 16. Spatial Daylight Autonomy Comparison – Floor 30 Figure 17. Spatial Daylight Autonomy Comparison – Northwest Façade Figure 18. Spatial Daylight Autonomy Comparison – Northeast Façade Figure 19. Spatial Daylight Autonomy Comparison – Southwest Façade Figure 20. Spatial Daylight Autonomy Comparison – Southeast Façade Figure 21. Annual Direct Sun Summary – Northwest Façade 	24 Error! Bookmark no 26 26 28 28 28 28 28
 Figure 13. 350 Mission Urban Context Figure 14. Spatial Daylight Autonomy Comparison – Floor 5 Figure 15. Spatial Daylight Autonomy Comparison – Floor 18 Figure 16. Spatial Daylight Autonomy Comparison – Floor 30 Figure 17. Spatial Daylight Autonomy Comparison – Northwest Façade Figure 18. Spatial Daylight Autonomy Comparison – Northeast Façade Figure 19. Spatial Daylight Autonomy Comparison – Southwest Façade Figure 20. Spatial Daylight Autonomy Comparison – Southeast Façade Figure 21. Annual Direct Sun Summary – Northwest Façade Figure 22. Annual Direct Sun Summary – Northeast Façade 	24 Error! Bookmark no 26 26 28 28 28 28 28 30 30
 Figure 13. 350 Mission Urban Context Figure 14. Spatial Daylight Autonomy Comparison – Floor 5 Figure 15. Spatial Daylight Autonomy Comparison – Floor 18 Figure 16. Spatial Daylight Autonomy Comparison – Floor 30 Figure 17. Spatial Daylight Autonomy Comparison – Northwest Façade Figure 18. Spatial Daylight Autonomy Comparison – Northeast Façade Figure 19. Spatial Daylight Autonomy Comparison – Southwest Façade Figure 20. Spatial Daylight Autonomy Comparison – Southeast Façade Figure 21. Annual Direct Sun Summary – Northwest Façade Figure 23. Annual Direct Sun Summary – Southwest Façade 	24 Error! Bookmark no 26 26 28 28 28 28 30 30 31

Figure 25. Lobby Space Allocation	34
Figure 26. Lobby General Circulation Lighting Rendering	
Figure 27. Public Art Example	
Figure 28. Office Floor Space Allocation	
Figure 29. Office Task Lighting	40
Figure 30. Office Floor Ceiling Coordination	41
Figure 31. DALI Integration with BACnet and FIM Systems	43
Figure 32. Lobby Control Zones	45
Figure 33. Office Floor Control Zones	48
Figure 34. Bus Duct Schematic	52
Figure 35. Office Level Floor Coordination	53
Figure 36. AC vs. DC VFD	55
Figure 37. Power Server Module Locations and DC Wiring	57
Figure 38. 350 Mission Boundary of Influence	59
Figure 39. Fuel Cell Cycle Summary	60
Figure 40. Isometric View of Lobby with Luminaire Swing Areas Defined	64
Figure 41. Electrical Riser Locations	65
Figure 42. Isometric View of Dual Riser System	65
Figure 43. Office Floor Power Plan	68
Figure 44. Building Equipment Summary	70
Figure 45. Office Floor – Fire Alarm Plan	71
Figure 46. Open Office and Circulation Speaker-Strobe Coverage	72
Figure 47. Open Office and Circulation Smoke Detector Coverage	73
Figure 48. Building Data Riser Schematic	74
Figure 49. Office Floor – Data and Telecommunications Floor Plan	75

Figure 50. LEED Point Summary	.76
Figure 51. Baseline vs. Designed Site Fuel Consumption by Building Component	.79
Figure 52. Net Present Value of Mechanical and Electrical Proposed Design Compared to Baseline	.80
Figure 53. Wind Velocity Map	.82
Figure 54. San Francisco Bay Bathymetry	.84
Figure 55. Offsite Solar Panel Analysis	.87
Figure 56. PG&E Renewable Energy Credit Purchase Price	.87
Figure 57. Offsite Solar Array Location	.88
Figure 58. Federal Incentives for Renewable Energy	.89
Figure 59. Detailed Façade Section	.90
Figure 60. Electrochromic Glass Cost Comparison – Sage Electronics	.92
Figure 61. Lobby Lighting Plan	.101
Figure 62. Lobby Pseudocolor Rendering	.102
Figure 63. Lobby Rendering with View of Public Art Wall	.103
Figure 64. Day and Nighttime Views of Lobby Lighting	.103
Figure 65. Office Floor Lighting Plan	.104
Figure 66. Office Pseudocolor Rendering	.105
Figure 67. Load Classification Schematic	.109
Figure 68. Fuel Cell PG&E Incentives	.115
Figure 69. Data System Schematic	.119
Figure 70. DGS Regulations for Pendant Mounted Luminaires in Earthquake Areas	.120
Figure 71. Isometric and Plan Views of Lobby with Luminaire Swing Areas Defined	.121

LIST OF TABLES

Table 1. System Overview Breakdown	1
Table 2. Spatial Daylight Autonomy Summary	19
Table 3. Spatial Daylight Autonomy Energy Savings	20
Table 4. Office Floor Surface Reflectance/Transmittance	23
Table 5. PPG Sungate 400 Glass Performance	23
Table 6. Surrounding Surface Reflectances	25
Table 7. Lobby Design Criteria	35
Table 8. Office Design Criteria	39
Table 9. Control System Design Criteria	42
Table 10. Lobby Lighting Controls Summary	44
Table 11. Office Floor Lighting Controls Summary	47
Table 12. 350 Mission Plug Load Controls Summary	67
Table 13. Expected Plug Load Energy Savings	67
Table 14. Office Receptacle Load Summary	69
Table 15. Rejected Onsite Energy Generation Methods	82
Table 16. Rejected Offsite Energy Generation Methods	84
Table 17. Onsite Solar Costs	85
Table 18. Onsite Solar Income/Incentives	85
Table 19. Portion of Onsite Solar Array Analysis Spreadsheet	85
Table 20. Offsite Solar Costs	88
Table 21. Offsite Solar Income/Incentives	88
Table 22. Electrochromic Glass Cost Analysis	91
Table 23. Lutron Cost Comparison Study – Price Summary	91
Table 24. Spatial Daylight Autonomy and Useful Daylight Illuminance Results – Northwest Façade	93

Table 25. Spatial Daylight Autonomy and Useful Daylight Illuminance Results – Northeast Façade	94
Table 26. Spatial Daylight Autonomy and Useful Daylight Illuminance Results – Southwest Façade	95
Table 27. Spatial Daylight Autonomy and Useful Daylight Illuminance Results – Southeast Façade	96
Table 28. Summary of Annual Direct Sun Hours	97
Table 29. Luminaire Schedule	99
Table 30. Space by Space Lighting Power Density Analysis	106
Table 31.Lighting Power Density Load Summary	107
Table 32. AC/DC Required Conversion Summary	108
Table 33. Office DC Voltage Drop Calculation Spreadsheet	110
Table 34. Building Load Summary	111
Table 35. Fuel Cell Analysis Summary	113
Table 36. Required Processing Power for Various Applications	116
Table 37. Computing Power Demand Comparison – Virtual vs. Traditional Computing	118

ACKNOWLEDGEMENTS

I would like to thank the following individuals for their support throughout the year, as this thesis would not have been possible without them.

The members of my thesis team, **AEVITAS**, for their hard work and cooperation in overcoming the challenges of designing in an interdisciplinary group, as well as for their much appreciated company on a number of late nights:

Robert Livorio Drew Canfield Kieran Carlisle Abigail Kreider Jonathan Sharp Kristin Sliwinski Alexander van Eeden

The Penn State faculty members who offered guidance throughout the design process:

Dr. Richard Mistrick Professor Moses Ling Professor Kevin Parfitt Dr. Ryan Solnosky Dr. Charles Cox Dr. Kevin Houser

The industry members who contributed their expertise and technical support:

Angela Matchica – EwingCole Mary Alcaraz – AKF Group Kathy Jooss – Pratt School of Engineering, Duke University Scott Wheaton – HGA Architects and Engineers Ryan Kannass – HGA Architects and Engineers

The companies that went above and beyond to provide product details and answer questions:

ClearEdge Power Nextek Power Systems Sun Light & Power

And finally, my family and friends who contributed more to my success than I could ever describe. They were a constant source of encouragement and support, and I cannot possibly thank them enough.

Very special thank yous go to my mother and father, Carol and Ed Kaiserian, for fielding countless phone calls throughout the year and for always knowing exactly what to say to get me back on track.

Chapter 1

Introduction

This project was completed as part of a joint effort between members of the lighting/electrical, construction, mechanical, and structural Architectural Engineering disciplines. The team, **AEVITAS**, was responsible for the design of all building systems, as well as the construction engineering for 350 Mission, a 30-story office highrise located in San Francisco, CA. The following report details the lighting and electrical systems design of the building, completed in collaboration with Robert Livorio.

Executive Summary

AEVITAS is an integrated design team, composed of representatives from the construction, structural, electrical, and mechanical disciplines. With the end goal of designing a net-zero high-rise building in the heart of San Francisco, **AEVITAS** developed the overarching attitude of [ZEROimpact], encompassing four focus areas of [ZEROinterruption], [ZEROenergy], [ZEROwaste], and [ZEROemissions]. Through a unified effort, **AEVITAS** achieved the net-zero design goals set forth at the beginning of the process. The design of 350 Mission is summarized in Table 1, and the lighting and electrical systems design is detailed in depth in this report.

ARCHITECTURAL	Floor Plan Changes, Vestibule Addition, Integrated Public Art Piece
FAÇADE	Natural Ventilation Louvers, Seismic Connections, Electrochromic Glazing
MECHANICAL	Radiant Floor System, Natural Ventilation Louvers, Dedicated Outdoor Air System
LIGHTING	LED Lighting, DALI Controls Responsive to Daylighting and Occupancy, Task Lighting
ENERGY GENERATION	Onsite Solar Array, Offsite Solar Array, Human Waste to Power Converter
ELECTRICAL	AC and DC Distribution, Natural Gas-Powered Fuel Cells, Dual Electrical Risers

Table 1. System Overview Breakdown

STRUCTURAL	Steel Superstructure, Braced Frame Core, Composite Beams and Deck, Outrigger
	System, Concrete Substructure
CONSTRUCTION	Production Planning, Matrix Scheduling, Waste Management, BIM Execution
	Planning, Site Planning

The lighting and electrical design strove to increase efficiency and decrease total energy consumption, and this was achieved through the use of a number of different strategies. The design focused on the lobby and a typical office floor, as well as whole-building systems design.

The desire to optimize daylighting and thermal properties of the glazing led to a façade design that benefitted both the mechanical systems and lighting design. Electrochromic glass is used on the façade of all office floors in place of shades to preserve views to the exterior and offer maximum flexibility to the occupants. Daylight photosensor dimming results in savings for the entire building, exceeding 100,000 kWh annually.

Efficient lighting design decisions, such as task lighting, resulted in a building lighting power density (LPD) of 0.434 W/sf, well below the 0.728 W/sf allowed by California Title 24 and CALGreen space-by-space method.

The building's electrical system features natural gas-powered fuel cells and both AC and DC distribution, designed to minimize conversion losses. The DC system feeds a server room that supports virtual computing on the office floors, saving almost 600,000 kWh of computer loads annually.

Taking the building's location in a seismic region into account, both the lighting and electrical design make special accommodations to ensure the safety of its occupants. The lighting follows guidelines for seismic design laid out by the California Department of General Services. The electrical system features dual emergency risers to give the building an added level of redundancy in a seismic event.

Energy is generated via onsite and offsite solar arrays, as well as an onsite human wasteto-power converter. These systems combined generate 5,544,000 kWh of energy annually, which is more than enough to cover the building's total expected annual consumption of 5,264,570 kWh.

350 Mission adheres to the traditional definition of net-zero by returning as much energy to the grid as it consumes in a year, and it also meets the broader goals defined by **AEVITAS** by minimizing emissions and waste and by creating a design that responds to the earthquake-prone environment to ensure continuity of operation even after a seismic event. Lifecycle cost analyses determined a payback period of 10.8 years for the mechanical systems and energy generation equipment.

The final building design successfully responds to the project requirements and achieves the project goals through the use of innovative and efficient design techniques.

Team Direction: Goals and Attitude

350 Mission is above all else, a collaboration. Through a joint effort, the concept of 'netzero building' has grown to fully encompass the idea of green living and **AEVITAS** is on the forefront of this movement. In order to reach the infinite goals that are stemming from such sustainable building ideas, **AEVITAS** set out to define the way the team would approach 350 Mission. Provided with an established architectural design but a different set of owner goals, the team has been dedicated to making design decisions that reflect the new goals of the owner, as well as the community and future tenants. **AEVITAS** is a talented team comprised of eight individuals with varying educations and diverse experience including backgrounds in structural design, MEP systems design, and construction engineering and management.

When coming together as a unified design force, the team as a whole was adamant early on about developing something more than a set of goals, something that would enable our interconnected thought process throughout design – our over-arching attitude. This attitude would encompass all team-driven specifications, with the owner profile and competition goals providing direction. From these motives, [ZEROimpact] was born. [ZEROimpact] is the way the project team defines the sustainable practices that are driving design decisions and owner goal integration. Within this all-encompassing team attitude and a strong mission statement, there are four focus areas that the goals are derived from, as shown below in Figure 1.

Taking an **integrated approach**, **AEVITAS** strives to **minimize environmental influences** by **engaging our community** with **sustainable** practices in energy conservation and emission reduction.



Design Process

All decisions were made using an integrated design process. Each option was weighed based on its impact on the project goals, potential impact on the other disciplines, and its pros and cons related to the lighting and electrical design. Compromises were made in order to make the decisions that were best for the building design as a whole, with no discipline consistently taking priority. Many lighting and electrical decisions were made by working to identify the most efficient option, as the [ZEROenergy] focus area was a main concern; however, this also had to be balanced with the task of creating an appealing and functional work environment.

Code Analysis

350 Mission was designed to the following codes and standards found within the California Building Standards Code (California Title 24):

- 2010 California Electrical Code and San Francisco Amendments
- 2010 California Energy Code and San Francisco Amendments
- 2010 California Fire Code and San Francisco Amendments
- California Green Building Standards Code (CALGreen)

California Title 24/California Energy Code is used in place of AHSRAE 90.1 for energy

standards. The California Green Building Standards Code (CALGreen) requires an additional

15% energy savings beyond the mandatory California Title 24 savings for green buildings.

Chapter 2

Energy

As with any 'net-zero' building, achieving net-zero energy consumption is one of the most important and challenging aspects. This is done in part by making educated design decisions to select the most efficient equipment and systems and reduce the overall energy consumption of the building, but it also requires the generation of energy to offset what the building must use in order to function properly.

Extensive research was conducted to determine the most viable energy generation tactics, both onsite and offsite. The selected technologies will be presented here. Information about the other systems that were investigated, as well as reasons for their dismissal, can be found in Appendix A.

Onsite Energy

Due to the location of the site, the relationship with the surrounding buildings, and the limited space, onsite energy generation alone was deemed inadequate to fulfill the needs of the building in a cost-effective manner. Wind, biomass, and geothermal generation, among other systems, were rejected due to findings related to the site. Two systems are being employed onsite, in combination with the offsite source outlined in the next section.

Onsite Solar Energy

Even though the building is not in an ideal location for onsite solar generation, analysis of the roof area showed that there is potential for some collection. Figures 2 and 3 show the potential kWh/m² values throughout the year, assuming 100% efficient panels and using typical

meteorological year (TMY) weather data. An efficiency multiplier of 0.15 and derate factor of 0.77 were applied to these initial values to determine that a roof solar array can produce 194,145 kWh of energy during an average year. Based on the available roof area, a 200kW array was selected.



Figure 2. Solar Radiation Map with Context

Through coordination with the mechanical and structural engineers, the mechanical cooling tower was placed below the roof surface in order to minimize possible shading of the panels due to the equipment. There is a hole in the roof above and space around the tower to allow for air flow. The addition of photovoltaic panels required a 4' parapet wall to be added around the cooling tower hole and building perimeter for safety. The calculations also take into account the amount of space required for maintenance walkways, as the potential kWh value was adjusted to exclude a percentage of the total roof area. Payback will occur in 12.4 years with 30% incentive coverage or 8.8 years with 50% incentive coverage. More information on the calculations and incentives can be found in Appendix B.



Figure 3. Roof Solar Radiation Map

Human Waste-to-Power

Normally, human waste is sent from buildings to a sewage treatment plant, where it can be refined to create fertilizer and water that is sometimes released into rivers and streams. Methane is released into the air, along with other undesirable gases. This is harmful to the environment, as well as being a waste of a potential energy source. 350 Mission will be equipped with a unit that utilizes supercritical water oxidation and gasification (SCWO/SCWG) to convert this waste into usable energy.

As summarized in Figure 4, waste moves from a holding tank into the cargo containersized unit. Its pressure and temperature are increased via high pressure pump and economizer. It is then sent to a reactor where it is combined with oxygen to produce a sterile combination of water, carbon dioxide, and inert salts.



The resulting steam is used to both sustain the supercritical combustion and operate a steam generator. This process and system are well-suited for use in a building because all of the waste-processing can take place onsite and requires no separation of wastes. SCWO can also process any other materials that find their way into the sewage.

It is estimated that this unit will generate 290,625 kWh per year and will pay back in 26 years on its own; however this period is shorter when combined with the rest of the building systems, and the benefit to the environment cannot be quantified. Calculations can be found in Appendix B.

Offsite Energy

After researching a number of offsite generation options, solar power was determined to be the most viable, based on system cost, site procurement, and permit requirements. It was selected over geothermal generation, tidal energy, and wind, as discussed in Appendix A. Rather than feeding 350 Mission directly, this solar installation will contribute to Pacific Gas and Electric's (PG&E) utility grid and offset 350 Mission's usage.



Figure 5. Annual Solar Radiation Map of the United States

The installation will be located in a secured compound in the Mojave Desert. This location is optimal for sunlight exposure and cost. Solar radiation maps of the United States, such as the one in Figure 5, show that it is one of the best locations in the country for harnessing solar power (outlined in red). In order to offset the remainder of the building's energy use, a 3.5 acre tract of land is required. With the addition of some space for maintenance paths and a security enclosure, as well as allowing the possibility of growth, a 10 acre tract of land was chosen. The cost of the selected plot, shown in Appendix B, is listed at \$13,000. A number of other lots of this size can be found at prices, on average, ranging between \$10,000 and \$20,000.

In order to offset the remainder of the building's energy usage that is not accounted for by onsite generation techniques, a 3000 kW PV array is required. An array of this size will cost about \$5,115,000.[1] While the price is steep, generous incentives are available for new installations. Local, state, and federal incentives may cover between 30-50% of the installation.

The fixed-tilt system is expected to generate 5,059,186 kWh of energy annually during an average weather year. This number takes into account site location, array tilt, and derating factors

that decrease the efficiency of the system. Fortunately, the size of the array will allow for a large inverter and transformer, which are much more efficient than smaller systems, and reduce the losses of converting direct current (DC) to alternating current (AC) for the grid. While fixed-tilt arrays generate about 20% less energy than axis-tracking systems, the added tracking feature comes with an increased price, maintenance, and potential for malfunction.

Energy can be sold to the utility company for \$0.10509/kWh assuming a 20-year contract starting in 2016 (the expected building completion year), and the payback period for the entire 3.5 acre array is 6.7 years with 30% covered by incentives, or 4.8 years with 50% covered by incentives. More information on the site, cost, and calculations can be found in Appendix B.

Chapter 3

Daylighting

Lobby Spatial Daylight Autonomy

The lobby is a four-story, 100% glass, open-air atrium located at the base of the building. Due to the relatively low light levels required in most of the space, daylighting alone can fill the circulation area requirements during the majority of daytime hours.

The lobby curtain wall uses double pane, low-e glass with a 55% visible light transmittance and 0.34 solar heat gain coefficient.

Integrating daylighting and electric light through the use of the building control system saves approximately 8,661 kWh annually.

Daylighting calculations were conducted using a spatial daylight autonomy (sDA) analysis. Spatial daylight autonomy shows the percent of occupied hours that the illuminance due to daylight at a certain point in a space exceeds the target illuminance. This can also be summarized for a space in a single number as the percent of points that have an illuminance exceeding the target for at least 50% of occupied hours. sDA numbers were used to estimate the energy savings due to daylighting in the 1st floor and 2nd floor lobby circulation spaces. The results are shown in Figures 6 and 7 along with a useful daylight illuminance (UDI) analysis.



The minimum was placed at 10 fc as that is the required illuminance in many of the transition spaces and the maximum at 500 fc as that is the upper limit set by the U.S. Green Building Council (USGBC) in the Leadership in Energy and Environmental Design (LEED) 2009 guidelines.

The spreadsheet showing the energy savings calculations is shown in Table 2 in the "Spatial Daylight Autonomy Calculations" section.

Office Façade Design

The façade design of 350 Mission required an integrated effort in order to engineer a system that would mutually benefit all disciplines. The design focused on making choices that would contribute to the [ZEROimpact] goal while also maintaining the woven aesthetic of the façade and the vision of the architect.

In collaboration with the mechanical engineers, the decision was made to alter the façade to optimize daylighting and mechanical savings. A daylighting study was conducted in order to determine the glass percentage that would allow a sufficient amount of daylighting without placing an unnecessary thermal burden on the mechanical systems. Figure 8 shows a view of the resulting façade design.



Figure 8. Façade Design with Panel Removed

The design includes an 8'-6" window with alternating tilted glass panes. Below this window is a natural ventilation box that contains operable louvers used to control the amount of outdoor air entering the space, based on environmental conditions and the demands of the mechanical system. A detailed façade section can be found in Appendix C.

Shading

The solar radiation maps shown in Figure 9 were used to determine that an automated shading system is required to maintain occupant comfort throughout the office floors.



Figure 9. Façade Solar Radiation Maps

As anticipated, the entire southwestern and southeastern facades receive a significant amount of solar radiation throughout the year. However, these radiation maps show that the northwestern and northeastern facades also receive considerable solar radiation and cannot be ignored when planning the shading system.

Rather than using traditional glass and fabric shades, 350 Mission will be equipped with electrochromic glass. This special glass receives an electrical signal that tells it to tint or untint based on commands sent by the control system. As the glass tints, it also adjusts its solar heat gain properties, with the solar heat gain coefficient ranging between 0.42 when clear and 0.09 when fully tinted. The visible light transmission can range from 60% in its clear state to 2% when

fully tinted. Depending on the size of the glass panels, desired tint level, and temperature, the tinting process takes between three and ten minutes.

Aside from controlling daylight, it can be used in conference rooms and other spaces where A/V presentations may take place. It can be integrated into the building control system and programmed to react to different environmental conditions or lighting scenes in a space.



Figure 10. Renderings of Untinted and Tinted Electrochromic Glass

Traditional shades, when lowered, obscure views to the outside far more than the tinted glass, and preserving these views was a priority for maximizing occupant comfort. When viewing the building from the outside, shades can negatively impact the building aesthetic by drastically taking away from the uniformity of the façade. Electrochromic glass will also lead to some variation on the façade, depending on the level of shading; however it will not be as noticeable from street level as traditional shades. Furthermore, it creates a façade that reacts to the building's surroundings to maximize energy savings. The mechanical implications of using electrochromic glazing are expected to be minimal, but the mechanical and electrical equipment have been sized to accommodate fluctuations in the cooling and heating load.

Electrochromic glass is used on the office floors in every façade section that borders an occupied space. Cost analysis revealed that it is equivalent cost-wise, if not less expensive, than

using traditional glass and shades. Details of the cost analysis can be found in Appendix C. Approximately 73,000 ft² of the building's glass will be electrochromic.

Application of the glass to all occupied spaces ensures that regardless of how the functions of the spaces and the floor layouts may change, all interior spaces will remain functional and comfortable for the occupants. It also eliminates the risk of surrounding buildings causing glare inside the building, as glass panes can be tinted as needed to maximize comfort.

Office Spatial Daylight Autonomy

In order to assess the office floors, sDA calculations were taken at the 5th, 18th, and 30th floors, and data was interpolated for the other office floors based on these results. For energy savings purposes, calculations assumed no shading system, as the glass can be adjusted to the exact level of transparency required to maximize the positive effects of the available daylight. Figure 11 summarizes the spatial daylight autonomy calculations for these key floors.



Figure 11. Open Office Daylight Autonomy

Spatial Daylight Autonomy Calculations

Using the information gathered from the sDA studies in the lobby and office floors, as well as the electric lighting layouts described in Chapter 5, calculations were conducted to estimate the potential annual daylight savings.

Lobby studies included the first and second floor circulation spaces, and office studies included open office and break/dining areas on various floors. Values were interpolated for intermediate floors.

Table 2 shows a summary of the spatial daylight autonomy values assumed for each space.

Table 2.	Snatial	Davlight	Autonomy	Summary
I doit #	Spana	Duyngne	ruconomy	Summary

Day	light Autor	nomy Sumn	nary										
Space	Floor	Threshold	DA Value					Daylight A	Autonomy	Definition			
		50 lux	100.0							- fara			-
	1ct Floor	100 lux	100.0		Р	ercentage	or the not	or area tha	t exceeds l	E _{target} for a	lieast 50%	or the tim	e
	ISL FIOOI	200 lux	100.0				Daylig	ht Autono	my Energy	Savings Ec	uation		
		300 lux	100.0		In the second	- 1 (0/ 61-		500/ - 6 Him				1 - L el	0.5
Lobby		50 lux	100.0		ĸwn sav	ea = (% j to	or area mei	50% of th	le)X(LPD of	space)x(to	tai nours of	lighting us	<i>e)x</i> <u>1000</u>
	2.1.5	100 lux	100.0										
	2nd Floor	200 lux	100.0		Energy S	avings Cal	culation G	eneral Info	ormation				
		300 lux	100.0		Lobby 1st	Floor Area	1	4700	ft. ²				
		50 lux	100.0		Lobby 2nd	Floor Are	а	2167	ft. ²				
		100 lux	91.9		Open Offi	ce Area		8350	ft. ² /floor				
	Low	200 lux	68.1		Dining/Br	eak Area		1347	ft. ² /floor				
		300 lux	53.3		Lobby Des	sign LPD		0.290	W/ft. ²				
		50 lux	100.0		Open Offi	ce Design	LPD	0.387	W/ft. ²				
Open		100 lux	96.3		Dining/Br	eak Design	LPD	0.145	W/ft. ²	Davlight	Hour Assu	mptions	
Office	Middle	200 lux	75.5		Lobby Ani	nual Lighti	ng	4015	hrs	7:00 am -	6:00 pm, 36	55 days	
		300 lux	61.2		Open Offi	ce Annual	Lighting	2800	hrs	7:00 am -	6:00 pm 25	0 days, 5	
		50 lux	100.0		Dining Bre	eak Annua	lighting	2800	hrs	hours on a	another 10	davs	
		100 lux	100.0		5			2000				aayo	
	High	200 lux	95.2										
		200 lux	82.2				Δηημ	al Lighting	Hours of L	ιςο Δεςιμη	ntions		
		50 lux	100.0		Assume th	nat all ligh	ting is at fu	Il output (no dimmir	οσ)	ptions		
	Low	100 lux	97 /		11 hours r	her dav (da	vlight hou	rs) 365 da	vs ner veai	15/ r			
Dining/		50 Jux	100.0		11 hours o	of use nerv	workday 2	250 workda	vs 5 hours	of use on	10 additio	nal davs	
Break	Middle	100 lux	100.0		11 hours o	of use per	workday, 2	50 workda	vs 5 hours	of use on	10 additio	nal days	
Dicuk		50 Jux	100.0		111100130	n use per	WOTKUUY, 2		ys, 5 110urs		10 000100	nai uays	
	High	100 lux	100.0										
		100107	100.0										
									Davi	ight Autor	omv	Davlight A	Autonomy
Daylig	ght Autono	my Approx	imated by	Floor	Dayli	ght Auton	omy Diffe	rence	Dayl Appro	ight Autor ximated b	iomy y Floor	Daylight A Diffe	Autonomy rence
Daylig	ght Autono	my Approx Open Office	imated by	Floor	Dayli	ght Auton Open	omy Diffe	rence	Dayl Appro	ight Autor ximated b ining/Brea	iomy y Floor ak	Daylight A Diffe	Autonomy rence /Break
Dayli Floor	sht Autono C	my Approx Open Office 100 lux	imated by 200 lux	Floor 300 lux	Dayli Floor	ght Auton Open 50 - 100	omy Diffe Office 100 - 200	200 - 300	Dayl Appro D Floor	ight Autor ximated b ining/Brea 50 lux	omy y Floor ak 100 lux	Daylight A Diffe Dining Floor	Autonomy rence /Break 50 - 100
Daylig Floor 5	sht Autono C 50 lux 100.0	my Approx Open Office 100 lux 91.9	imated by 200 lux 68.1	Floor 300 lux 53.3	Dayli Floor 5	ght Auton Open 50 - 100 8.1	omy Diffe Office 100 - 200 23.8	200 - 300 14.7	Dayl Appro D Floor 5	ight Autor ximated b ining/Brea 50 lux 100.0	omy y Floor ak 100 lux 97.4	Daylight A Diffe Dining Floor 5	Autonomy rence /Break 50 - 100 2.6
Daylig Floor 5 6	th Autono C 50 lux 100.0 100.0	my Approx Open Office 100 lux 91.9 92.3	imated by 200 lux 68.1 68.7	Floor 300 lux 53.3 54.0	Dayli Floor 5 6	ght Auton Open 50 - 100 8.1 7.7	omy Diffe Office 100 - 200 23.8 23.6	200 - 300 14.7 14.7	Dayl Appro D Floor 5 6	ight Autor ximated b ining/Brea 50 lux 100.0 100.0	omy y Floor ak 100 lux 97.4 97.7	Daylight A Diffe Dining Floor 5 6	Autonomy rence /Break 50 - 100 2.6 2.3
Daylig Floor 5 6 7	th Autono 50 lux 100.0 100.0 100.0	my Approx Dpen Office 100 lux 91.9 92.3 92.6	imated by 200 lux 68.1 68.7 69.3	Floor 300 lux 53.3 54.0 54.6	Dayli Floor 5 6 7	ght Auton Open 50 - 100 8.1 7.7 7.4	omy Diffe Office 100 - 200 23.8 23.6 23.3	200 - 300 14.7 14.7 14.7	Dayl Appro D Floor 5 6 7	ight Auton ximated b ining/Brea 50 lux 100.0 100.0 100.0	omy y Floor ak 100 lux 97.4 97.7 97.9	Daylight A Diffe Dining Floor 5 6 7	Autonomy rence /Break 50 - 100 2.6 2.3 2.1
Daylig Floor 5 6 7 8	th Autono 50 lux 100.0 100.0 100.0 100.0	my Approx Open Office 100 lux 91.9 92.3 92.6 93.0	imated by 200 lux 68.1 68.7 69.3 69.9	Floor 300 lux 53.3 54.0 54.6 55.3	Dayli Floor 5 6 7 8	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0	Office 100 - 200 23.8 23.6 23.3 23.1	200 - 300 14.7 14.7 14.7 14.7	Dayl Appro D Floor 5 6 7 8	ight Autor ximated b ining/Brea 50 lux 100.0 100.0 100.0 100.0	bomy y Floor ak 100 lux 97.4 97.7 97.9 98.1	Daylight A Differ Dining Floor 5 6 7 8	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9
Daylig Floor 6 7 8 9	th Autono 50 lux 100.0 100.0 100.0 100.0 100.0	Deen Office 100 lux 91.9 92.3 92.6 93.0 93.4	imated by 200 lux 68.1 68.7 69.3 69.9 70.6	Floor 300 lux 53.3 54.0 54.6 55.3 56.0	Dayli Floor 5 6 7 8 9	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6	Office 100 - 200 23.8 23.6 23.3 23.1 22.8	200 - 300 14.7 14.7 14.7 14.6 14.6	Dayl Appro D Floor 5 6 7 7 8 9	ight Autor ximated b ining/Brea 50 lux 100.0 100.0 100.0 100.0 100.0	bomy y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3	Daylight A Differ Dining Floor 5 6 7 8 9	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7
Daylig Floor 5 6 7 8 9 10	th Autono 50 lux 100.0 100.0 100.0 100.0 100.0 100.0	Deen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2	Floor 300 lux 53.3 54.0 54.6 55.3 56.0 56.6	Dayli Floor 5 6 7 8 9 10	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2	Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6	Dayl Appro D Floor 5 6 7 7 8 9 9	ight Autor ximated b ining/Brea 50 lux 100.0 100.0 100.0 100.0 100.0 100.0	omy y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3 98.5	Daylight A Diffe Dining Floor 5 6 7 8 9 9	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5
Daylig Floor 5 6 7 8 9 10 11	c 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0	Deen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8	300 lux 53.3 54.0 54.6 55.3 56.0 56.6 57.3	Dayli Floor 5 6 7 8 9 10 11	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9	Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.6 14.5	Dayl Appro D Floor 5 6 7 7 8 9 9 10	ight Autor ximated b ining/Brea 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0	omy y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7	Daylight A Differ Dining Floor 5 6 6 7 7 8 9 9 10 11	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3
Daylig Floor 5 6 7 8 9 10 11 11	th Autono 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx 2pen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5	imated by 200 lux 68.1 69.3 69.9 70.6 71.2 71.8 72.4	Floor 300 lux 53.3 54.0 55.3 56.0 56.6 57.3 57.9	Dayli Floor 5 6 7 8 8 9 10 11 11	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1	200 - 300 14.7 14.7 14.6 14.6 14.6 14.6 14.5 14.5	Dayl Appro D Floor 5 6 7 7 8 8 9 10 11	ining/Breat 50 lux 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9	Daylight A Differ Dining Floor 5 6 7 7 8 9 10 11 11	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1
Daylig Floor 5 6 7 8 9 10 11 11 12 14	sht Autono 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx Dpen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0	Floor 300 lux 53.3 54.0 54.6 55.3 56.0 56.6 57.3 57.9 58.6	Dayli Floor 5 7 8 8 9 9 10 11 11 12 2 14	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 2 5.9 5.5 5.1	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.6 22.3 22.1 21.8	200 - 300 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5	Dayl Appro D Floor 5 6 7 7 8 9 9 0 10 11 11 12 2 14	ight Autor ximated b ining/Brea 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	y Floor ak 100 lux 97.4 97.9 98.1 98.3 98.5 98.7 98.9 98.9	Daylight A Diffe Dining Floor 5 6 7 7 8 9 9 100 111 122 14	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9
Daylig Floor 5 6 7 8 9 10 11 12 14 14 15	sht Autono 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx Deen Office 100 lux 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6	Floor 300 lux 53.3 54.0 55.3 56.0 56.6 57.3 57.9 58.6 59.2	Dayli Floor 5 7 8 8 9 9 10 11 11 12 2 14 4	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6 6.2 5.9 5.5 5.1 4.8	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6	200 - 300 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5	Dayl Appro D Floor 7 8 9 9 10 11 11 12 2 14	ight Autor ximated b ining/Brea 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	y Floor ak 100 lux 97.4 97.9 98.1 98.3 98.5 98.7 98.9 98.9 99.1 99.4	Daylight A Differ Dining Floor 5 6 7 7 8 9 9 100 111 122 144 15	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9 0.6
Daylig Floor 5 6 7 8 9 10 11 12 14 15 16	sht Autono 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx 2pen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 95.6	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3	Floor 300 lux 53.3 54.0 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9	Dayli Floor 5 6 7 7 8 8 9 9 10 11 11 12 2 14 4 5 5 6	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3	200 - 300 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4	Dayl Appro D Floor 7 8 9 9 10 11 11 12 2 14 4 5 5 6	ight Autor ximated b ining/Brea 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	y Floor ak 100 lux 97.4 97.9 98.1 98.3 98.5 98.7 98.9 98.9 99.1 99.4	Daylight A Differ Dining Floor 7 8 9 9 100 111 122 144 155 16	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9 0.6 0.4
Daylig Floor 5 6 7 8 9 10 11 12 14 15 16 6 17	sht Autono 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx Dpen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 94.9 94.9 95.2 95.6 96.0	200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 73.6 74.3 74.9	Floor 300 lux 53.3 54.0 54.6 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 59.9 60.5	Dayli Floor 5 6 7 8 9 9 10 11 11 12 14 15 15 17	ght Auton Open 50 - 100 8.1 7.7 7.4 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4	Dayl Appro D Floor 5 6 7 7 8 9 10 11 12 2 14 4 4 5 16 17	ight Autor ximated b ining/Breat 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.4 99.4	Daylight A Diffe Dining Floor 5 6 7 7 8 9 9 100 111 122 144 155 166 17	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.3 1.1 0.9 0.6 0.4 0.2
Daylig Floor 5 6 7 8 9 9 10 11 12 14 15 16 177 18	sht Autono 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx Dpen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 94.9 94.9 95.2 95.2 95.6 96.0 96.3	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 73.6 73.6 74.3 74.9 74.5	Floor 300 lux 53.3 54.0 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2	Dayli Floor 5 6 7 8 8 9 9 10 11 11 12 14 15 16 17 7 18	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 20.8	200 - 300 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4 14.4	Dayl Appro D Floor 5 6 7 7 8 9 10 11 12 11 12 14 15 16 16 17	ight Autor ximated b ining/Breat 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.4 99.6 99.8	Daylight A Diffe Dining Floor 5 6 7 7 8 9 9 100 111 122 144 155 166 177	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.9 1.7 1.5 1.3 1.3 1.1 0.9 0.6 0.4 0.4 0.2 0.0
Daylig Floor 5 6 7 8 9 9 10 11 12 14 15 16 17 18 19	sht Autono 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx Dpen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 94.9 95.2 95.6 96.0 96.3 96.6	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3 74.3 74.9 75.5 77.1	Floor 300 lux 53.3 54.0 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 60.5 60.2 62.9	Dayli Floor 5 6 7 8 9 9 10 11 11 12 14 15 16 17 18 19	ght Auton Open 50 - 100 8.11 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7 3.4	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.1 21.8 21.6 21.3 21.1 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.6 21.3 21.6 21.8 21.6 21.6 21.8 21.6 21.6 21.6 21.6 21.6 21.6 21.6 21.6	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4 14.4 14.3 14.2	Dayl Appro D Floor 5 6 6 7 7 8 8 9 9 10 10 11 11 12 2 14 4 15 16 17 18 19	ight Autor ximated b ining/Brea 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	y Floor y Floor 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.4 99.6 99.8 100.0 100.0	Daylight A Differ Dining Floor 5 6 6 7 7 8 9 9 10 11 12 12 14 15 16 17 18 19	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.9 1.7 1.5 1.3 1.1 0.9 0.6 0.6 0.4 0.2 0.0 0.0
Daylig Floor 5 6 7 8 9 9 10 11 11 12 14 15 16 17 17 18 19 9 20	sht Autono 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx Dpen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 94.9 95.2 95.6 96.0 96.3 96.6 97.0	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3 74.9 74.9 75.5 77.1 78.8	Floor 300 lux 53.3 54.0 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 60.5 60.5 61.2 62.9 64.7	Dayli Floor 5 6 7 8 9 9 10 10 11 12 14 15 16 17 18 18 19 200	ght Auton Open 50 - 100 8.11 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.4 4.0 3.7 3.4 3.0	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 20.8 21.1 20.8 19.5 18.2	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4 14.4 14.3 14.2 14.2	Dayl Appro D Floor 5 6 6 7 7 8 9 9 10 10 11 12 2 14 4 15 16 17 18 19 200	ight Autor ximated b ining/Brea 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	y Floor y Floor 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.4 99.6 99.8 100.0 100.0	Daylight A Differ Dining Floor 5 6 6 7 7 8 9 9 10 10 11 12 12 14 14 15 16 17 18 19 200	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.9 1.7 1.5 1.3 1.1 0.9 0.6 0.4 0.4 0.2 0.0 0.0 0.0 0.0 0.0
Daylig Floor 5 6 7 8 9 9 10 11 11 12 14 15 16 17 18 19 200 20	sht Autono 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx Dpen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 95.6 96.0 96.3 96.3 96.3 96.3 97.0 97.3	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3 74.9 75.5 77.1 78.8 88,80,4	Floor 300 lux 53.3 54.0 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2 62.9 64.7 66.4	Dayli Floor 5 6 7 8 9 9 10 11 12 14 15 16 17 18 19 20 20 20	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7 3.4 3.0 2.7	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 20.8 21.5 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.8 21.8 21.6 21.8 21.6 21.8 21.6 21.8 21.6 21.8 21.8 21.6 21.8 21.6 21.8 21.8 21.8 21.8 21.8 21.8 21.8 21.8	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4 14.4 14.4	Dayl Appro D Floor 5 6 6 7 8 9 9 10 10 11 12 12 14 14 15 16 16 17 7 18 19 20 20	ight Autor ximated b ining/Brea 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	y Floor y Floor 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.6 99.8 100.0 100.0 100.0 100.0 100.0	Daylight A Differ Dining Floor 6 7 8 9 9 10 10 11 12 14 14 15 16 17 18 19 20 20	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9 0.6 0.4 0.2 0.0 0.0 0.0 0.0 0.0 0.0
Daylig Floor 5 6 7 8 9 9 10 11 11 12 14 15 16 16 17 18 19 20 20 21 1 22	sht Autono 50 lux 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx Dpen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 95.6 96.0 96.3 96.3 96.3 97.0 97.3 97.6	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3 74.9 75.5 77.1 78.8 80.4 880.4 82.1	Floor 300 lux 53.3 54.0 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2 62.9 64.7 66.4 68.2	Dayli Floor 5 6 7 8 9 9 10 11 12 14 15 16 17 18 19 20 21 1 22	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7 3.4 3.0 2.77 2.4	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.5 5 18.2 16.5	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4 14.4 14.4	Dayl Appro D Floor 5 6 6 7 8 9 9 10 11 12 12 14 14 15 5 16 17 7 8 9 9 20 21 21 22	ight Autor ximated b ining/Brea 50 lux 100.0	y Floor y Floor 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.6 99.8 100.0 100.0 100.0 100.0 100.0 100.0	Daylight A Differ Dining Floor 6 7 8 9 9 10 10 11 12 12 14 14 15 16 17 18 19 20 20 21 21	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9 0.6 0.4 0.2 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
Daylig Floor 5 6 7 8 9 9 10 11 11 12 14 15 16 17 18 19 20 21 22 23	sht Autono 50 lux 50 lux 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0 100.0	my Approx Dpen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 95.6 96.0 96.6 96.3 96.3 96.3 97.0 97.3 97.6 97.9	imated by 200 lux 68.1 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3 74.9 75.5 77.1 78.8 80.4 82.1 83.7	Floor 300 lux 53.3 54.0 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2 62.9 64.7 62.9 64.7 66.4 68.2 69.9	Dayli Floor 5 6 7 8 9 9 10 11 12 14 14 15 16 17 18 19 20 20 21 22 23	ght Auton Open 50 - 100 8.11 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.88 4.4 4.0 3.7 3.4 3.0 2.7 2.44 2.1	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 20.8 19.5 18.2 16.8 15.5 14.1	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4 14.4 14.4	Dayl Appro D Floor 5 6 6 7 8 9 9 10 11 12 14 14 15 5 16 17 7 8 9 20 20 21 22 23	ight Autor ximated b ining/Brea 50 lux 100.0	y Floor y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.6 99.8 100.0 100.	Daylight A Differ Dining Floor 6 7 8 9 9 10 11 11 12 12 14 14 15 16 16 17 7 18 19 20 20 20 21 22	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9 0.6 0.4 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
Daylig Floor 5 6 7 8 9 100 111 122 144 155 166 177 188 199 200 211 222 233 244	sht Autono 50 lux 100.0	my Approx pen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 95.6 96.0 96.6 96.0 96.3 96.6 97.0 97.3 97.6 97.9 97.9 98.2	imated by 200 lux 68.1 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3 74.9 75.5 77.1 78.8 80.4 82.1 83.7 85.4	Floor 300 lux 53.3 54.0 54.6 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2 62.9 64.7 66.4 68.2 69.9 64.7 66.4 68.2 69.9 71.7	Dayli Floor 5 6 7 8 9 9 10 11 12 14 15 16 17 18 19 20 21 22 22 23 24	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7 3.4 3.0 2.7 2.4 2.1 1.8	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 20.8 19.5 18.2 16.8 15.5 14.1 12.8	200 - 300 14.7 14.7 14.6 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4 14.4 14.4	Dayl Appro D Floor 5 6 6 7 8 9 9 10 11 12 12 14 15 16 16 17 7 8 8 19 20 21 22 23 24	ight Autor ximated b ining/Brea 50 lux 100.0	y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.4 99.6 99.8 100.0	Daylight A Differ Dining Floor 5 6 6 7 7 8 8 9 9 10 11 11 12 12 14 14 15 16 16 17 7 8 8 19 20 21 22 22 23	Autonomy rence /Break 50 - 100 2.6 2.3 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9 0.6 0.0 0.0 0.00 0.00 0.00 0.00 0.0
Daylig Floor 5 6 7 8 9 10 11 12 14 15 16 17 18 19 20 21 22 23 24 25	sht Autono 50 lux 100.0	my Approx pen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 95.6 96.0 96.6 96.0 96.3 96.6 97.0 97.3 97.6 97.9 97.2 97.8 97.9 97.8 97.9 97.9 98.2 98.2 98.2 98.2 97.9 97.9 97.9 98.2 98.2 98.2 98.2 97.9 97.8 97.9 98.2	imated by 200 lux 68.1 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3 74.9 75.5 77.1 78.8 80.4 82.1 83.7 83.7 83.7 83.4 87.0	Floor 300 lux 53.3 54.0 54.6 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2 62.9 64.7 66.4 68.2 69.9 71.7 73.4	Dayli Floor 5 6 7 8 9 9 10 11 12 12 14 15 16 16 17 7 8 19 20 21 22 23 23 24 25	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7 3.4 3.0 2.7 2.4 2.1 1.8 1.8	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 20.8 19.5 18.2 16.8 15.5 14.1 12.8	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.5 14.4 14.4 14.4	Dayl Appro D Floor 5 6 6 7 7 8 8 9 9 10 11 12 12 14 14 15 16 16 17 7 8 8 19 20 20 21 22 23 24 24 25	ight Autor ximated b ining/Brea 50 lux 100.0	y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.6 99.8 100.0	Daylight A Differ Dining Floor 5 66 7 7 8 8 9 9 10 11 11 12 12 14 14 15 16 16 17 7 20 20 21 22 23 23 24	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9 0.6 0.6 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
Daylig Floor 5 6 7 8 9 10 11 12 144 155 166 177 18 19 200 211 222 233 24 25 26	sht Autono 50 lux 100.0 10.	my Approx pen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 95.6 96.0 96.3 96.6 97.0 97.3 97.6 97.9 97.9 98.2 98.5 98.2 98.5 98.8	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3 74.9 75.5 77.1 78.8 80.4 82.1 83.7 83.7 83.7 85.4 85.4 85.4	Floor 300 lux 53.3 54.0 54.6 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2 62.9 64.7 66.4 68.2 69.9 71.7 73.4 75.2	Dayli Floor 5 6 7 8 9 9 10 11 12 12 14 15 16 17 18 19 20 21 22 23 24 24 25 26 25 26	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7 3.4 3.0 2.7 2.4 2.1 1.8 1.5 1.5 1.5 1.5 1.5 1.5 1.5 1.5	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 20.8 19.5 18.2 16.8 15.5 14.1 12.8 11.5 10.1	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4 14.4 14.4	Dayl Appro D Floor 5 6 6 7 7 8 8 9 9 10 11 12 12 14 14 15 16 17 7 8 8 19 20 20 21 22 23 24 25 26 25 26 26	ight Autor ximated b ining/Brea 50 lux 100.0	y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.4 99.6 99.8 100.0	Daylight A Dining Floor 5 6 6 7 7 8 8 9 9 10 11 12 12 14 14 15 16 16 17 18 19 20 21 22 23 24 24 25 25	Autonomy rence 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.3 1.1 0.9 0.6 0.6 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
Daylig Floor 5 66 7 8 9 100 111 122 144 155 166 177 188 199 200 211 222 233 244 255 266 77	sht Autono 50 lux 100.0 100	my Approx pen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 95.6 96.0 96.3 96.6 97.0 97.3 97.6 97.9 97.9 98.2 98.5 98.8 99.1	imated by 200 lux 68.1 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3 74.9 75.5 77.1 78.8 80.4 82.1 83.7 85.4 83.7 85.4 83.7 85.4 87.0 88.7 90.3	Floor 300 lux 53.3 54.0 54.6 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2 62.9 64.7 66.4 68.2 69.9 71.7 75.4 75.2 75.9	Dayli Floor 5 6 7 8 9 10 11 12 14 15 16 17 18 19 20 21 22 23 24 25 26 7 7	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7 3.4 4.3 0 0 2.7 2.4 2.1 1.8 1.5 1.2 0 0	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 20.8 19.5 18.2 16.8 15.5 14.1 12.8 11.5 10.1 8	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4 14.4 14.4	Dayl Appro D Floor 5 6 6 7 7 8 8 9 9 10 11 12 14 15 16 17 7 8 19 20 20 21 22 23 24 22 23 24 25 26 7 7	ight Autor ximated b ining/Brea 50 lux 100.0 100	y Floor ak 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.4 99.6 99.8 100.0	Daylight A Dining Floor 5 6 7 7 8 8 9 9 10 11 11 12 12 14 15 16 16 17 18 19 20 21 12 22 23 24 22 23 24 25 25 25 27	Autonomy rence 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9 0.6 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
Daylig Floor 5 6 7 8 9 100 111 122 144 155 166 177 188 199 200 211 222 233 244 255 266 277 28	sht Autono 50 lux 100.0 100	my Approx Deen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.4 93.8 94.1 94.5 94.9 95.2 95.6 96.0 96.0 96.0 97.0 97.3 97.6 97.9 98.2 98.5 98.8 98.5 98.5 98.5 98.4	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 74.3 73.6 74.3 73.6 74.3 73.6 74.3 74.9 75.5 77.1 78.8 80.4 82.1 83.7 85.4 80.4 83.7 85.4 87.0 88.7 90.3 92.0	Floor 300 lux 53.3 54.0 54.6 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2 62.9 64.7 66.4 68.2 69.9 71.7 73.4 75.2 76.9 78.7 78.9	Dayli Floor 5 6 7 8 9 9 10 11 12 14 15 166 17 18 19 20 21 22 23 24 25 26 27 28	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7 3.4 3.0 2.7 2.4 2.1 1.8 1.5 1.2 0.9 0.6 6 6 6 6 6 6 6 6 6 6 6 6 6	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 20.8 19.5 18.2 16.8 15.5 14.1 12.88 11.5 10.1 8.8 7.4 7.4 7.4 7.4 7.4 7.4 7.4 7.4	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.5 14.4 14.4 14.4	Dayl Appro D Floor Floor 5 6 6 7 7 8 8 9 9 10 11 12 22 14 14 15 16 16 17 7 8 19 20 21 12 22 23 24 24 25 26 27 7 28	ight Autor ximated b ining/Brea 50 lux 100.0	y Floor ak 100 lux 97.4 97.7 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.6 99.8 100.0	Daylight A Dining Floor 5 6 7 7 8 8 9 9 10 11 11 12 14 15 16 16 17 18 19 20 21 17 22 23 24 24 25 26 26 27 7	Autonomy rence 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9 0.9 0.6 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
Daylig Floor 5 6 7 8 9 100 111 122 144 155 166 177 188 199 200 211 222 233 244 255 266 277 28 29	sht Autono 50 lux 100.0	my Approx Deen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.4 93.8 94.1 94.5 94.9 95.2 95.6 96.0 96.0 96.0 96.3 96.6 97.0 97.3 97.6 97.9 98.2 98.5 98.8 99.1 99.4 99.4 99.4 99.4 99.4 99.4	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 73.6 74.3 74.9 75.5 77.1 78.8 80.4 82.1 83.7 85.4 83.7 85.4 83.7 85.4 83.7 92.0 93.6 93.0 93.6	Floor 300 lux 53.3 54.0 54.6 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2 62.9 64.7 66.4 68.2 69.9 71.7 73.4 75.2 76.9 78.7 80.4	Dayli Floor 5 6 7 8 9 9 10 11 12 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29	ght Auton Open 50 - 100 8.1 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7 3.4 3.0 2.7 2.4 2.1 1.8 1.5 1.2 0.9 0.6 0.3 0.9 0.9 0.9 0.9 0.9 0.9 0.9 0.9	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 20.8 19.5 18.2 16.8 15.5 14.1 12.88 11.5 10.1 8.8 7.4 6 1	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.5 14.4 14.4 14.4	Dayl Appro D Floor Floor 5 6 6 7 7 8 8 9 9 10 11 12 12 14 15 16 16 17 7 8 19 20 21 1 22 23 24 24 25 26 27 28 29	ight Autor ximated b ining/Brea 50 lux 100.0 100	y Floor ak 100 lux 97.4 97.7 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.6 99.8 100.0	Daylight A Dining Floor 5 6 7 7 8 8 9 9 10 10 11 12 12 14 15 16 16 17 18 19 20 21 14 22 23 24 25 26 26 27 27 28 29	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 1.7 0.9 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
Daylig Floor 5 6 7 8 9 100 111 122 14 15 166 177 18 19 200 211 222 23 24 25 266 277 28 29 20 20	sht Autono 50 lux 50 lux 100.0	my Approx Deen Office 100 lux 91.9 92.3 92.6 93.0 93.4 93.8 94.1 94.5 94.9 95.2 95.6 96.0 96.0 96.3 96.6 97.0 97.3 97.6 97.9 98.2 98.5 98.8 99.1 99.4 99.7 100 0	imated by 200 lux 68.1 68.7 69.3 69.9 70.6 71.2 71.8 72.4 73.0 73.6 73.6 73.6 73.6 73.6 73.6 73.5 77.1 78.8 80.4 82.1 83.7 85.4 83.7 85.4 83.7 90.3 92.0 93.6 93.6 93.6 93.6 93.6 93.6 93.6 93.6	Floor 300 lux 53.3 54.0 54.6 55.3 56.0 56.6 57.3 57.9 58.6 59.2 59.9 60.5 61.2 62.9 64.7 66.4 68.2 69.9 71.7 73.4 75.2 76.9 78.7 80.4 78.7 80.4 82.2 78.7 80.4 82.2 78.7 78	Dayli Floor 5 6 7 8 9 9 10 10 11 12 14 15 16 16 16 16 17 7 18 8 20 20 21 22 23 24 25 26 27 7 28 29 30	ght Auton Open 50 - 100 8.11 7.7 7.4 7.0 6.6 6.2 5.9 5.5 5.1 4.8 4.4 4.0 3.7 3.4 4.3 0 2.7 3.4 1.5 1.2 0.9 0.6 0.3 0.0 0.0 0.0 0.0 0.0 0.0 0.0	omy Diffe Office 100 - 200 23.8 23.6 23.3 23.1 22.8 22.6 22.3 22.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.3 21.1 21.8 21.6 21.8 21.1 21.8 21.6 21.8 21.1 21.8 21.6 21.8 21.6 21.8 21.1 21.8 21.6 21.8 21.6 21.8 21.6 21.8 21.6 21.8 21.6 21.8 21.6 21.8 21.6 21.8 21.6 21.8 21.6 21.5 21.6 21.5 21.6 21.5 21.6 21.5 21.6 21.5 21.6 21.5 21.6 21.5 21.6 21.5 21.6 21.5 21.5 21.5 21.5 21.5 21.5 21.5 21.5	200 - 300 14.7 14.7 14.7 14.6 14.6 14.6 14.5 14.5 14.5 14.5 14.4 14.4 14.4 14.4	Dayl Appro D Floor 5 6 6 7 7 8 9 9 10 10 11 11 12 2 14 14 15 16 17 18 19 20 20 21 22 23 24 24 25 26 27 7 28 29 9 20	ight Autor ximated b ining/Brea 50 lux 100.0	y Floor y Floor 100 lux 97.4 97.7 97.9 98.1 98.3 98.5 98.7 98.9 99.1 99.4 99.4 99.4 99.4 99.6 99.8 100.0 100.	Daylight A Differ Dining Floor 5 6 6 7 7 8 9 9 10 10 11 11 12 12 14 15 16 17 17 16 17 20 20 21 22 23 24 24 25 26 27 28 26 27 28 30 0	Autonomy rence /Break 50 - 100 2.6 2.3 2.1 1.9 1.7 1.5 1.3 1.1 0.9 0.6 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0

Daylight Autonomy Energy Savings [kwh]			Daylight Autonomy Energy Savings [kwh]			Daylight Autonomy Savings Summary					
Floor	Open Office	Dining/Break	1st Floo	or 2nd I	Floor	Lobby 1st	Floor	5928	kwh	annually	
5	3278	270	5928	2733		<mark>Lobby 2n</mark>	d Floor	2733	kwh	annually	
6	3300	270				<mark>Open Off</mark>	ice	90998	kwh	annually	
7	3322	271				Dining/B	reak	6813	kwh	annually	
8	3344	271				Total		106473	kwh	annually	
9	3366	271									
10	3388	271									
11	3410	272									
12	3432	272									
14	3454	272									
15	3476	273									
16	3498	273									
17	3519	273									
18	3541	273									
19	3595	273									
20	3648	273									
21	3702	273									
22	3755	273									
23	3809	273									
24	3863	273									
25	3916	273									
26	3970	273									
27	4023	273									
28	4077	273									
29	4130	273									
30	4184	273									
Totals	90998	6813									

Table 3. Spatial Daylight Autonomy Energy Savings

The potential energy savings shown in Table 3 combine the sDA values with the lighting power densities achieved through the electric lighting design.

The spatial daylight autonomy study concluded that the use of a daylighting control system in the lobby circulation, open office, and dining/break areas has the potential to save 106,473 kWh annually.

Chapter 4

Urban Daylighting Study

The initial daylighting analyses described in Chapter 3 yielded interesting results when comparing the interior illuminance values between different floors and façade orientations. The led to the desire to conduct a separate study to further explore the impact of an urban environment on the daylighting potential of a building. A new, simplified building model was constructed in an attempt to make the results applicable to a wider range of buildings; however, the results for two buildings will never be the same when taking into account all factors including surrounding buildings' locations and heights, façade orientation, and floor plan, among others. This chapter details the process used to conduct the study, as well as summarizes the findings.

Scope of Study

Results do not reflect the conditions inside the building as they would appear during actual occupancy, as shades were not included in the study. The purpose of this study is simply to make comparisons between the amount of daylight entering each space and draw conclusions based on the façade orientations and surrounding buildings. This is not necessarily all usable daylight, as shades would be applied in cases of direct sun and high illuminance levels.

A direct sun study was conducted to estimate the annual number of occupied hours when the shading system will likely be employed due to direct sun.

All factors, excluding floor height and façade orientation, were held constant to make the comparison as accurate as possible. While results do not necessarily reflect actual office conditions, as there is no furniture, the intent of the study was to make comparisons between the

various trials. Since all trials make the same assumptions, they can be compared to one another, even though they cannot necessarily be compared to outside results.

A direct sun study was also conducted to help make assumptions about the number of hours each year when shade application would be absolutely necessary. This only provides an estimate of hours when shades will be down due to direct sun, not those when the illuminance levels in the space are too high; however these can be approximated using the daylight autonomy at 500 fc, the maximum set by LEED for usable daylight.

The Model

The building footprint is 130'-4" x 122'-10", and the 40'-8" x 51'-6" core is centered in the floor plan. Six columns are evenly spaced along each façade. The floor is divided into separate areas for the four façade orientations, as shown by the green, yellow, red, and blue areas in Figure 12.



Figure 12. AutoCAD Office Floor Model

The analysis areas extend 24' into the space, and 10' tall floor-to-ceiling windows wrap

around the entire floor.

The individual floor model was inserted into a city model that included 350 Mission in its entirety, as well as the surrounding buildings that were expected to have an impact on the amount of daylight in the space.

Three floors were evaluated – the 5th, 18th, and 30th. These are the bottom, middle, and top office floors and are 54', 236', and 418' from street level, respectively.

The reflectance and transmittance values used for the office floor are summarized in Table 4.

Table 4. Office Floor Surface Reflectance/Transmittance					
Surface	Reflectance/ Transmittance				
Ceiling	0.80				
Floor	0.20				
Core/Columns	0.50				
Windows	0.55				

The glass transmittance value assumed the use of PPG Sungate 400 Passive Low-e glass,

as seen in Table 5.

Table 5, 11 G Sungate 400 Glass Ferror mance											
Glass Type		Transmittance		Reflectance		U-Value (Imperial)				Solar	Light to
		Visible %	Total Solar Energy %	Visible Light %	Total Solar Energy %	Winter Night- time	Summer Day- time	European U-Value	Coeffi- cient	Gain Coeffi- cient	Solar Gain (LSG)
Insulating Vision Unit Performance Comparisons 1-inch (25mm) units with 1/2-inch (13mm) airspace and two 1/4-inch (6						ı (6mm) li	tes; interi	or lite cle	ar		
SUNGATE® 400 Low-E	SUNGATE® 400 Low-E										
SUNGATE 400 (2) Clear + Clear	28	76	51	14	16	0.32	0.31	1.8	0.69	0.60	1.27
SUNGATE 400 (2) STARPHIRE + STARPH	RE 39	80	65	14	20	0.32	0.31	1.8	0.78	0.68	1.18
Clear + SUNGATE 400 (3) Clear	28	76	51	14	17	0.32	0.31	1.8	0.73	0.63	1.21
STARPHIRE + SUNGATE 400 (3) STARPH	RE 39	80	65	14	22	0.32	0.31	1.8	0.83	0.73	1.10
SOLEXIA + SUNGATE 400 (3) Clear	15	66	33	11	9	0.32	0.31	1.8	0.50	0.44	1.50
ATLANTICA + SUNGATE 400 (3) Clear	8	58	25	10	7	0.32	0.31	1.8	0.40	0.35	1.66
AZURIA + SUNGATE 400 (3) Clear	20	59	25	10	7	0.32	0.31	1.8	0.39	0.34	1.74
PACIFICA + SUNGATE 400 (3) Clear	7	37	19	7	6	0.32	0.31	1.8	0.34	0.30	1.23
SOLARBLUE + SUNGATE 400 (3) Clear	15	48	31	8	9	0.32	0.31	1.8	0.49	0.42	1.14
SOLARBRONZE + SUNGATE 400 (3) Clear	12	46	32	8	10	0.32	0.31	1.8	0.50	0.44	1.05
SOLARGRAY + SUNGATE 400 (3) Clear	12	38	27	7	9	0.32	0.31	1.8	0.44	0.39	0.97
GRAYLITE II + SUNGATE 400 (3) Clear		8	5	4	5	0.32	0.31	1.8	0.17	0.15	0.53
OPTIBLUE + SUNGATE 400 (3) Clear		55	41	9	13	0.32	0.31	1.8	0.62	0.54	1.02

Table 5. PPG Sungate 400 Glass Performance

It also assumes five foot windows supported by four inch mullions, causing a mullion factor of 0.93. The combination of this mullion factor with the 59% visible light transmittance of the glass resulted in the 0.55 window transmittance value.

Surrounding Buildings

The daylight in a space is greatly impacted by the building's surroundings. In an urban context, where buildings are close together and are often very tall, the impact is even more significant. Figure 13 shows the buildings surrounding 350 Mission, as well as their heights.



Figure 13. 350 Mission Urban Context

350 Mission is situated in a valley of much taller buildings. 50 Fremont, Transbay Tower, and Millennium Tower, located south of the building, are all 150' taller at minimum. The Blue Shield of California Building is not taller; however its façade is only 40' away from the northeast façade of 350 Mission.

The surrounding building reflectances were estimated and are summarized in Table 6.

Table 6. Surrounding Surface Reflectances						
Building	Reflectance					
Transbay Tower	0.10					
50 Fremont	0.41					
425 Market	0.26					
45 Fremont	0.36					
333 Market	0.25					
Blue Shield of California	0.07					
Pacific Gas and Electric	0.30					
Providian Financial	0.36					
199 Fremont	0.28					
Millennium Tower	0.25					
Ground	0.15					

The Trials

Using Daysim, trials were run for each of the twelve analysis areas (three floors, four facades/analysis areas per floor). Daylight autonomy values were gathered for each area at various footcandle values: 10, 20, 30, 50, 100, 250, 500, and 1000. Useful daylight illuminance images were also generated, setting the boundaries at 25 fc for the minimum and 500 fc for the maximum, as these are the values set by LEED 2009 as the acceptable range for useful daylight [12].

Calculation grids were 4' x 3', with the 4' dimension running parallel to the windows and the 3' dimension running perpendicular. Points were raised 2.5' off of the ground to simulate typical workplane height.

For the direct sunlight study, a line of points was applied to the windows on the twelve façade/floor combinations. These points were placed 5' from the bottom of the windows and spaced 4' apart. One trial was conducted with surrounding buildings, and the other was conducted with the building completely isolated in order to analyze the impact of the surrounding buildings on the amount of direct sunlight that reaches the façade.

Occupancy was assumed from 6AM - 7PM, Monday - Friday throughout the entire year.
The Results

Spatial Daylight Autonomy

A selection of the resulting spatial daylight autonomy images can be seen in Appendix D, and the results are summarized in Figures 14-20. Figures 14-16 compare the sDA values for the different facades at each floor.





Figure 14. Spatial Daylight Autonomy Comparison - Floor 5





Figure 16. Spatial Daylight Autonomy Comparison – Floor 30

The floor comparison presents some interesting results. On the lower floors, the southeast and southwest façades yield higher spatial daylight autonomy values. The difference between the north façades and south façades is the most obvious on Floor 5, shown in Figure 14. Here, the north façades are dramatically affected by the neighboring buildings, and this is compounded by the fact that the façades are north facing. By Floor 18, the difference is not quite as large; however, Figure 15 still clearly shows two pairs of lines – the two north façades and the two south façades. These results were expected, as the south facing façades are generally the focus when designing to avoid intrusive daylight.

An interesting switch occurs on Floor 30. The northeast façade, formerly the bottom curve, became the façade with the highest daylight autonomy values. Just as surprising, the second highest curve is the northwest façade. After looking at the building model, the reason for this difference becomes clearer. At Floor 30, the northeast façade no longer has a neighboring building blocking it, making it very easy for daylight to enter the space. The northwest façade still has a taller building at this level, but it is only about 25' taller. This clearly does not have as much of an impact.

The southeast and southwest façades face taller buildings, and these are the tallest in the area. Even at Floor 30, their presence has a considerable impact on the daylighting potential in the space.

Figures 17-20 compare the spatial daylight autonomy values on different floors for each façade.













Figure 20. Spatial Daylight Autonomy Comparison – Southeast Façade

The façade comparison graphs reinforce the conclusions drawn from the floor comparison graphs. In the northwest and northeast graphs, the curves representing Floor 30 are dramatically difference from those for Floor 5 and Floor 18. Even without looking at the city model, it is obvious that there is an external factor that changes at Floor 30, creating the substantial difference reflected in the graphs. In the southwest and southeast graphs, on the other hand, the curves for each floor follow a similar shape, and the higher floors receive more sunlight, as expected. These consistent curve shapes show that the relative impact of the surrounding buildings remains the same at all floors, and this conclusion is supported by the geometry and the fact that the southwest and southeast buildings are much taller than 350 Mission.

Annual Direct Sun

Figures 21-24 summarize the results of the direct sun study. Numerical values for the annual hours of direct sun for each façade and floor can be found in Appendix D.

The graphs show the annual hours of direct sun at each calculation point, moving across the façade from left to right as viewed from the building exterior.







Figure 22. Annual Direct Sun Summary – Northeast Façade

30



Figure 23. Annual Direct Sun Summary – Southwest Façade



Figure 24. Annual Direct Sun Summary – Southeast Façade

31

The southwest façade receives the most direct sun, even after the surrounding buildings are factored in. For all façades, with the exception of the northeast, the addition of the surroundings reduces the hours of direct sun exposure by more than 50% over the course of the year. In the case of 350 Mission specifically, the northeast is not affected as dramatically due to the height of the neighboring building. Floor 30, as expected, is affected the least, as the neighboring building's roof is below this level.

During the hours when there is direct sun incident on the building façade, it is likely that the use of a shading system would be required to maintain a comfortable working space.

Conclusions

This urban daylighting study reinforces the idea that context is important when designing a building system. Without taking measurements and doing studies such as this one, a designer may assume that the south facing façades are the only ones of concern, whereas this study clearly showed that is not the case. The daylight conditions on different floors of a highrise building are greatly affected by the floor height, the height of surrounding buildings, façade orientation, and the distance of the surrounding buildings from the building façades. The large number of factors that affect the daylighting in a space make it critical to use simulations to aid in design, and most importantly, to create models that accurately and completely include the building's surroundings.

Chapter 5

Electric Lighting

Lighting Design Concept

Prior to designing the electric lighting for 350 Mission, design criteria and a concept were developed in order to guide design decisions and ensure that each one was made with the project goals in mind.

350 Mission is located in the SoMa (South of Market) neighborhood of San Francisco. This area used to be called "South of Slots", referring to the cable cars that once dominated the streets. Paying tribute to the history of the area, the concept for the lighting design is cable cars. These represent the innovation of the city, as San Francisco was the first to implement a cable car system. Even now, San Francisco is a leader in energy efficiency and recycling programs. The lighting design for 350 Mission builds on these traditions of innovation and efficiency. Linear forms can be found throughout the design, reminiscent of the cable car tracks and wires that still line the streets of San Francisco.

After developing the concept and design criteria outlined in the following sections and evaluating the various available light source options, LED lighting was chosen as the primary source for 350 Mission due to its low energy consumption and competitive color rendering and glare control properties. Dimming is an important part of the lighting control system to ensure that energy is not wasted, and is also inherently favorable to LED luminaires by decreasing the amount of heat that needs to be exhausted and contributing positively to luminaire life and resistance to color shift.

In storage rooms and other back-of-house spaces, fluorescent lighting will be used as it is more cost-effective and will not be in use as frequently as the lighting in the public and office spaces.

Lobby

Although the lobby is a big, open space, it has a variety of separate functions. These include circulation, reception, retail, and gathering areas, as shown in Figure 25.



Figure 25. Lobby Space Allocation

The lighting design strives to clearly distinguish the separation of these areas, as well as address the other design criteria listed in Table 7. Quantitative criteria were defined by the Illuminating Engineering Society (IES) illuminance requirements for the various building space functions.

Table 7. Lobby Design Criteria									
Qualitative									
Guide visitors to key points									
Maximize use of daylight									
Integrated with/enhance architecture									
Create visual interest									
• Visually reduce scale of the lobby									
• Earthquake-conscious design									
• Separate various functions of the open space									
• CRI above 80	• CRI above 80								
• CCT – 4000K	ССТ – 4000К								
Quantitative (values are in fc)									
Space Type	Criteria	Actual							
Circulation	10	10.5							
Elevator Lobby	10	10.4							
Stairs 10 10									
Security Desk 30 34									
Vestibule 15 14.1									

Linear luminaires configured into squares are suspended from the drop ceiling, as shown in Figure 26, providing enough light for general ambiance. The design is decorative to make the lobby visually interesting, even when electric lighting is not needed, and the hollow centers of the luminaires avoid detracting from the architecture. The restaurant and east corner retail area have been left to allow flexibility to the future tenants. Some adjustable ambient lighting is supplied in the east corner retail area, mounted via monorails extending from the partition walls. The rest will be integrated into the displays brought in by the tenants. Receptacles are provided in the floor for this purpose.

35



Figure 26. Lobby General Circulation Lighting Rendering

More information about the special considerations for general circulation area lighting can be found in the "Seismic Design" section in Chapter 6. The lighting plan can be found in Appendix E.

The lobby lighting design resulted in an LPD of 0.41 W/sf, as compared to the 0.97 W/sf allowed by code.

Public Art

The San Francisco Planning Department requires that new construction projects allocate 1% of the total construction cost of the building to publicly displayable art. Originally, architect's vision for the space included a three-story LED media canvas. While this is a novel way to interact with the public and attract people to the lobby, its operation would require a substantial amount of energy, which is not ideal for a building aiming to be highly energy efficient. The new design transforms the space into a similar public attraction, but one using less energy. A design competition will be held for local artists to create a mural that incorporates dynamic lighting effects to be installed on the feature wall, as shown in Figure 27, and people in the lobby will have the opportunity to interact with the art and the building by using the power of their footsteps.



Figure 27. Public Art Example

PaveGen tiles are energy-generating floor tiles that use piezoelectric polymer material to convert kinetic energy produced by human foot traffic to electricity. The technology is a new kind of renewable energy, one that directly interacts with humans, but it is not yet a realistic source of building-scale energy generation as the electrical output is too low and the cost too high. As an integrated part of the work of art, however, the PaveGen tiles can be purchased under the public art allowance. The tiles will be installed throughout the lobby floor in a pattern determined by the artist, with each tile activating some portion of the lighting in the mural. In this way, people walking across the lobby will interact with the public art using the kinetic energy of their footsteps. The higher the level of interaction with the floor tiles, the more the dynamic lighting on the wall reacts.

As important as energy efficient building systems are to creating a near net-zero highrise, occupant participation is also critical to minimizing energy use. The interactive art display is intended to make the building occupants more conscious of their role in conserving, and even in this case, creating energy. Since the luminaires used in the wall are only on when triggered by a floor tile, the energy requirements are quite low, and the tiles are sufficient to supply the display.

The electric lighting in the lobby was coordinated with the public art wall to ensure that the view of the wall is not obstructed by suspended luminaires from any location in the lobby from which the wall is visible. Views showing this coordination and other renderings can be found in Appendix E.

Office

The office area consists of an open office area, smaller conference and meeting rooms, a break room, and circulation space. These spaces are defined in Figure 28.



Figure 28. Office Floor Space Allocation

The driving forces behind the lighting design of the office floors were simplicity, energy

efficiency, and user flexibility. Energy efficiency on the office floors is especially important because the energy savings resulting from this lighting design are multiplied by 25 (the number of office floors). A summary of the office design criteria can be found in Table 8.

1 able 8. Office Design Criteria									
Qualitative									
• Create a welcoming, work-friendly environment									
• Provide as much controlled daylight as possible									
• Prevent glare on computer screens, desks, etc.									
• Avoid visual clutter									
• CRI above 80									
• CCT – 4000K									
Quantitative (values are in fc)									
Space Type	Criteria	Actual							
Open Office-Desk	30	30.6							
Open Office-Circ.	10	15.2							
Circulation	11.8								
Small Conference	30	29.7							
Large Conference	30	30.1							
Kitchen	30	29.9							
Dining/Break Area	10	10.7							
Restroom	5	5.5							
Copy Room 10 12.0									

The primary ambient lighting comes from continuous runs of linear LED fixtures. The fixtures use diffuse lenses and a low lumen package to reduce the risk of glare. They are placed above the partitions between rows of desks to avoid shadowing on the work area and glare on computer screens. Overhead lighting only provides 2/3 of the required maintained illuminance levels, with the other 10 fc provided by dimmable LED task luminaires. These luminaires have adjustable arms for maximum flexibility and are mounted to the front partition on each desk, as shown in Figure 29.



Figure 29. Office Task Lighting

Employees can choose whether or not they need the task lights after evaluating light levels from daylighting and the overhead lighting. Task lighting is the most efficient means of delivering light to the workplane, and combining this with the overhead lighting reduces the lighting load on the office floors. The office lighting design resulted in an LPD of 0.42 W/sf, as compared to the code allowable 0.76 W/sf. The lighting plan, as well as a summary of all building lighting power densities, can be found in Appendix E.

The lighting design was also coordinated with the mechanical and electrical systems. All recessed luminaires extend into the plenum less than six inches to create more space for mechanical ductwork and dampers. The DC electrical distribution, detailed further in Chapter 5, also runs through the plenum and feeds all of the ceiling recessed lighting, low voltage controls, and telecom devices. Linear mechanical diffusers are installed to match the linear luminaires over the open office workstations. This ceiling coordination is shown in Figure 30, with luminaires shown in red, ductwork and diffusers shown in blue, and electrical power server modules shown in green.



Figure 30. Office Floor Ceiling Coordination

Emergency Lighting

The emergency lighting provides one foot-candle of horizontal illuminance at the floor along the path of egress, as required by the California Building Code. This includes all stairwells, corridors, and travel routes that building occupants must take to reach these egress paths, including large partitioned rooms and utility spaces. In both the lobby and office floors, emergency lighting is integrated into the normal lighting design. To accommodate this, the emergency panel is supplied by normal and emergency power supplies and controlled by an automatic transfer switch (ATS). The power server modules (discussed further in the "AC/DC Distribution" section in Chapter 6) that receive the 380VDC and convert it to 24VDC have multiple inputs, one from the normal panel and one from the emergency panel, and are programmed so that only the output channels supporting emergency loads draw power from the emergency panel when the normal feed stops.

Controls

A Digitally Addressable Lighting Interface (DALI) system is used to control the glass tinting and electric lighting in the building.

Table 9. Control System Design Criteria								
Qualitative								
•	Monitor energy use							
٠	Minimize energy use							
٠	Comply with code							
٠	Maximize safety							
٠	Seamless integration of daylight and electric							
	lighting							
٠	Flexible							
•	Control electric lighting and shading systems							
٠	Dimming in daylit spaces							
٠	Maximize occupant comfort							
•	Integrate with Building Automation System (BAS)							

This lighting control system was selected after developing the design criteria listed in Table 9, and is tied into a Building Automation and Control Network (BACnet) that also manages the mechanical systems in the building, as shown in Figure 31.



Figure 31. DALI Integration with BACnet and FIM Systems

These systems function within the definition of the Facilities Integration Model (FIM). This model is created by the general contractor and specialty contractors during construction and is handed over to the building owner and facilities manager after the building is completed. Aside from controlling the lighting, electrical, and mechanical systems, the FIM also contains product data, making replacement of parts more efficient and ensuring that product information is available to the facilities manager throughout the lifetime of the building.

The integration of these systems allows the building operations team to view a summary of the building's energy use, aiding in the identification of systems that are not performing as anticipated and permitting analysis of how the building is performing in regards to the net-zero goal. The offsite solar array is also monitored, sending information back to the main building control system for inclusion in the overall building energy use reports.

The DALI system for lighting control allows for two-way communication between the central control station and each associated device. The control system can both send signals to the

devices, telling the lights to dim or the glass to tint, and receive signals from the devices, informing the operator of failed drivers or motors or of LEDs that have reached the end of useful life. DALI is also an open standard, so a wide variety of manufacturers offer devices and luminaires that are compatible, removing any interoperability limitations.

In all locations where LEDs are used, the control system is programmed to adjust power input throughout the LED life to maintain a constant lumen output. Calculations were performed with a 0.7 lumen depreciation factor, and without an adjustment by the control system, areas will be considerably over lit. There is a linear relationship between power input and lumen output, so the initial input for each LED fixture will be 70% of the maximum. Light levels will be monitored via photosensors that tell the control system when the LEDs have depreciated to the point where electric light levels are too low and the power input needs to be increased. Doing this saves energy while also maintaining appropriate light levels, making the spaces more comfortable for the occupants.

Lobby

The lobby is divided into separate control areas based on function. A summary of the lobby controls can be found in Table 10.

SPACE TYPE	MANUAL ON	MANUAL OFF	DIMMING	OVERRIDE SWITCH	MULTI SCENE CONTROLLER	KEY SWITCH	TIME CLOCK ON	TIME CLOCK OFF	OCCUPANCY SENSOR ON	OCCUPANCY SENSOR OFF	PHOTOCONTROL DIMMING
General Circulation Area											Х
Reception Desk – task	Х	Х								Х	
Reception Desk – decorative							Х	Х			
Retail – ambient			Х	Х			Х	Х			Х
Retail – merchandise			Х				Х	Х			
Elevator Lobby							Х	Х	Х	Х	

Table 10. Lobby Lighting Controls Summary

The complete controls narrative is below. The lobby control zones reference the areas





Figure 32. Lobby Control Zones

General Circulation Area CZ1

The suspended luminaires in the general circulation area are on from dusk to dawn for security purposes and throughout the day as needed. They are controlled by multiple photosensors attached to the fixtures and calibrated to approximate the ground illuminance levels. The lights dim as daylight levels allow, and when the amount of daylight in the lobby is adequate for general circulation, the lights are turned completely off. Each luminaire is controlled individually due to the size and layout of the lobby, ensuring that the entire space will have adequate light levels regardless of the time of day or exterior conditions.

Reception Desk CZ2

The reception desk lighting is divided into two groups – task lighting on the desktop area and decorative lighting underneath the desk. The task lighting is controlled by a manual on/off and occupancy sensor off. Throughout much of the day, this lighting will likely not be necessary as the daylight values in the space are more than adequate. However, it is available if needed. The decorative lighting is time clock controlled, turning on at 6AM and off at 7PM each day.

Retail CZ3-CZ4

There are two retail areas, one underneath the stairs to the second floor and the other at the east corner of the building. The stair retail area has ceiling recessed fixtures that are switched together and have manual on/time clock off controls, with the time clock set based on store operating hours.

The east corner retail area has two levels of lighting – ambient and merchandise lighting. The ambient lighting has time clock on/off controls, set to remain on during operating hours. These lights can be dimmed based on the tenant requirements, and there is an override switch in case of housekeeping or other after-hours usage. Due to the store's location, ambient luminaires are also controlled by a photosensor and are dimmed/switched off when daylight levels allow.

The merchandise lighting in this area is also controlled by a time clock on and off; however this can be set separately from the ambient lighting to allow the tenant to light merchandise during closed hours for advertising and security purposes. This lighting is flexible and can be dimmed as desired by the tenant.

Elevator Lobby CZ5

The elevator lobby is controlled by a time clock for the majority of the work day, turning all lights on at 6AM and off at 7PM. Outside of these hours, occupancy sensors are responsible for the on/off controls.

Vestibule CZ6-CZ7

Vestibule lighting is controlled primarily via a time clock that switches the lights on when the building opens in the morning and off when it closes at night. During the day, it is also controlled by a photosensor that dims and switches the lights when there is enough daylight to do so. All of the lights in each vestibule are controlled together.

Office

As the office layout is flexible, the lighting controls are described as they would be designed for the typical floor layout that is being used as the standard. Due to the flexibility offered by DALI control systems, any changes made to the floor plan after the initial programming can be reflected in an adjustment of the control system settings to fit the new specifications.

SPACE TYPE	MANUAL ON	MANUAL OFF	DIMMING	OVERRIDE SWITCH	MULTI SCENE CONTROLLER	KEY SWITCH	TIME CLOCK ON	TIME CLOCK OFF	OCCUPANCY SENSOR ON	OCCUPANCY SENSOR OFF	PHOTOCONTROL DIMMING
Open Office – overhead	Х			Х				Х			Х
Open Office – task lighting	Х	Х								Х	
Flex Space	Х			Х				Х			Х
Electrical/Mechanical Rooms	Х	Х								Х	
Restrooms									Х	Х	
Elevator Lobby							Х	Х	Х	Х	
Corridors							Х	Х	Х	Х	
Copy Room									Х	Х	
Interview Rooms	Х	Х								Х	
Teleconference Rooms	Х	Х	Х							X	
Conference Rooms	Х	Х	Х		X					X	
Dining/Break Area									Х	X	Х
Kitchen									X	Х	

 Table 11. Office Floor Lighting Controls Summary

A summary of the office floor controls can be found in Table 11. The complete office

controls narrative is below and references the control zones shown in Figure 33.



Figure 33. Office Floor Control Zones

Open Office/Flex Space CZ1-CZ5

The open office lighting consists of the overhead lights and the task lighting on each workstation. Task lighting is locally controlled, only turning on when switched on by an occupant. These lights can either be switched off manually or a vacancy sensor located under each desk does so automatically after a preset period of time.

The overhead lighting is controlled by a manual "on" at the beginning of each day, with each fixture being assigned to a control zone as designated by the red outlines. At 6:00PM each day, lights blink several times as a five minute shutoff warning. If the override switch is not activated during that time, the lights turn off at 6:05PM. Use of the override causes lights in the specified control area to remain on for an additional 90 minutes, and at the end of this additional time, the same shutoff warning occurs. The override option is available to all employees through the use of the Voice over Internet Protocol (VoIP) phones located at each desk or the physical override switches located in the vicinity of each control zone.

During hours where daylight harvesting is possible, lights dim according to the signals received by closed-loop daylight sensors located in the ceiling. Each control zone is also divided into dimming zones. Luminaires of the same color in the same control zone are controlled by one photocell to prevent each fixture from dimming to a different level, as occupants generally prefer dimming to occur in groups rather than each fixture dimming individually.

An override switch is also provided for housekeeping. CZ1 and CZ2 are controlled by the same housekeeping switch, and CZ3-CZ5 are controlled together. When the housekeeping override is activated, lights in the designated zones will turn on for 30 minutes. These are the only spaces in which a housekeeping override is required, as most other areas on the office floor are occupancy sensor controlled.

Mechanical Room CZ6

These fluorescent luminaires are controlled with a manual on/off as well as occupancy sensor off. The controls for the rest of the electrical/telecom/etc. spaces (unmarked on the plan) are the same as this room. Switches are located at the entrances to each room and control all of the lights in the area.

Restrooms CZ7-CZ8

The restrooms are controlled solely by occupancy sensors. There is a wall switch sensor at the entrance to the room, as well as ceiling mounted occupancy sensors in the stall area to ensure that the lights do not turn off while occupants are in the restroom.

Elevator Lobby CZ9

The elevator lobby is controlled by a time clock for the majority of the work day, turning all lights on at 7AM and off at 6PM. Outside of these hours, occupancy sensors are responsible for the on/off controls.

Corridors CZ10-CZ13

Similar to the elevator lobby, the corridors are controlled by time clock to constantly remain on from 7AM-6PM. At other times, occupancy sensors assume control, and lights only turn on when a sensor is triggered. The luminaires located in each control zone are controlled as a group, and occupancy sensors are located as required to ensure that lights turn on when the corridor area is occupied.

Copy Room CZ14

The copy room uses an occupancy sensor for on/off control at all hours.

Interview Rooms CZ15-CZ17

Interview rooms utilize a manual on/off switch located at the door, as well as a vacancy sensor to prevent lights from staying on and wasting energy while the room is unoccupied.

Teleconference Rooms CZ18-CZ21

Similar to the interview rooms, the teleconference rooms have a manual on/off controller at the door and a vacancy sensor. In addition, the wall controller allows for dimming to accommodate the various light level needs depending on the current function of the room.

Conference Rooms CZ22-CZ23

Conference rooms are equipped with scene controllers to accommodate the variety of activities that may occur in these spaces. They can be used for formal and informal meetings, brainstorming sessions, audio/visual presentations, etc. The lighting requirements for each of these scenarios are different, and scenes are programmed for each. A/V presentation mode turns

off the majority of lights, excluding the two rear downlights, and the electrochromic glass on the façade will tint to allow for better screen visibility. Meeting mode consists of all lights turned on. Other scenes can be programmed into the controller as the needs of the tenants require. There is also a vacancy sensor to ensure that lights are off when the room is not being used.

Dining/Break Area CZ24

Occupancy sensors located in the break area control on/off switching of the luminaires. The control zone also contains two photosensor dimming zones, shown by the luminaire colors in the control diagram.

Kitchen CZ25

The kitchen is controlled by occupancy sensors that switch the lights on and off.

Large Conference Room CZ26

This conference room also has a scene controller to accommodate the variety of activities that may take place, including meetings, presentations, training sessions, etc. A/V presentation mode turns off the front lights, dims the middle, and leaves the front lights on. It also shades the glass. Normal presentation mode has the same luminaire controls, but the glass does not tint. Other scenes can be programmed into the controller as the needs of the tenants require. There is also a vacancy sensor to ensure that lights are off when the room is not being used.

Chapter 6

Electrical Design

AC/DC Distribution

The electrical system in 350 Mission was designed to maximize efficiency, utilizing dual alternating current and direct current (AC/DC) electrical distribution to support building loads. While AC infrastructure is the industry standard, the popularity of DC power distribution is on the rise. Semiconductor-based loads, including LED lighting, computer servers, and low voltage controls inherently require DC voltage, making the standard practice of converting AC distribution to low voltage DC at each device inefficient. Renewable onsite energy generation can also directly interface with DC distribution systems, eliminating the need for an inverter.



As shown in Figure 34, the utility-paralleling AC switchgear is located adjacent to the PG&E vault in the primary electrical space on level B1 and distributes normal and emergency power via a 480VAC bus duct running vertically through the electrical rooms in the core. The DC switchgear, also in parallel with the utility and receiving input from both onsite energy sources, is located in the penthouse. Its distribution runs through a separate 380VDC bus duct also running through the electrical rooms in the core. An additional emergency riser runs vertically through the electrical closet and will be discussed in the "Seismic Design" section. The bus ducts act as large feeders, allowing power taps using bus plugs to "plug" into the copper runs where power is needed. This offers greater end-use flexibility by eliminating individual feeders and consolidating vertical runs into a large bus accessible at plug locations.



Figure 35. Office Level Floor Coordination

The AC and DC bus ducts are contacted at each office floor and in the lobby spaces to provide power to main circuit breaker (MCB) panels, the AC panel via a small step-down transformer. Panelboards feeding the restaurant and retail areas are separately metered to monitor the energy use of those vendors. AC distribution runs primarily under the floor slab of the floor below and pokes through the slab at receptacle junctions, and DC distribution runs in the ceiling plenum. The AC distribution locations were coordinated with the mechanical radiant floor system, as shown in Figure 35.

Maintaining AC distribution throughout the building was necessary for receptacles feeding electronics and appliances that have not yet penetrated the DC market. For example, the desktop computer loads at each office floor run on AC distribution because the market is dominated by AC computer power supply units (PSUs). The building's computers are discussed in more detail in the "Server Room" section. A detailed schematic showing the AC/DC breakdown of building loads and the electrical riser diagram can be found in Appendix F.

Concerning capital cost, the dual AC/DC system presents a tradeoff between quantity and size. It requires more equipment to accommodate the two voltage distributions, but components can be smaller as the building load is divided. Realistically, the dual system presents at least some increase in equipment and installation costs, but this should pay for itself as the DC distribution is expected to result in a 5% increase in efficiency at a very minimum.[2]

Mechanical

350 Mission's approximately 350 kW of connected mechanical equipment requiring power runs on 380VDC. While AC and DC motors have similar efficiencies depending on the size and manufacturer, DC variable frequency drives (VFDs) offer a significant advantage over AC.



Figure 36. AC vs. DC VFD

As shown in Figure 36, a VFD supporting an AC motor and receiving AC input experiences two conversions, AC-DC and then DC-AC, whereas a VFD feeding a DC motor with DC input experiences no conversions. Every device has heat and mechanical losses, but eliminating conversions is the key to improving system efficiency. The DC motor and VFD combination allows pumps and fans to maintain near-peak efficiency even when running at partial load, which is critical considering that all mechanical equipment is oversized to some degree. Mechanical loads also generally have lower power factors than other equipment, but with DC distribution there are no phases, so this is not an issue.

Lighting

Before considering energy savings for daylight harvesting and controls, electric lighting is expected to consume 30% of the building's energy use. Therefore, making the electrical system feeding the lighting as efficient as possible was critical. The branch panelboard in the lobby, restaurant and office floor electrical rooms is fed by the 380VDC bus duct and distributes 380VDC to the 2 kW and 123 kW of connected lighting in the lobby and the 25 office floors, respectively. With almost 16,000 ft2 of office space, the 380VDC is distributed as close to the loads as possible using strategically located power server modules (PSMs). The modules then convert 380VDC to 24VDC at an efficiency of over 96%, with the 24VDC distribution reaching the lighting, controls, and other low voltage loads through one of the 16 95W output channels.

Each output channel operates independently, so the power to several luminaires can be turned off without disrupting the others. Control wires for the DALI system run separately from the power wiring. The modules can also receive more than one input, allowing emergency circuits to also be connected to a module serving normal loads. Under normal operating conditions, all loads in the module are served by normal power, and only the emergency channels are served by the emergency feed if necessary.

Six PSMs supply all of the 24VDC loads on each office floor, aside from the actuators in the façade, which have their own DC-DC converters. In order to verify that the voltage drop on each branch circuit does not exceed 3%, as recommended by the National Electrical Code (NEC), the placement of the power server modules and wiring to the lighting fixtures was anticipated for the typical office layout. Figure 37 shows the layout and wiring of the circuits to guarantee that the voltage drop on all branch circuits, from DC panel to PSM to load, remains under 3%. The spreadsheet used to conduct these calculations can be found in Appendix F. 12 AWG conductors were used, as this is the same size that is typically found on AC lighting circuits.



Figure 37. Power Server Module Locations and DC Wiring

With these modules, distribution happens at a higher voltage, preventing voltage drop and allowing the use of the same wire sizes found in a typical AC system. Each module receives the 380VDC distribution voltage and converts it to 24VDC through various output channels for use by the LED DC-DC drivers and DC fluorescent ballasts. From the DC switchgear to each luminaire, the voltage experiences only one 96% efficient conversion at the power server module and minor losses within the DC-DC drivers that regulate the 24VDC current for dimming.

Façade

The actuators that adjust and hold the natural ventilation louvers are located every ten feet within the system. They run on 24VDC and are supplied via the 380VDC panelboard on each office floor, with one 90% efficient 380VDC to 24VDC conversion occurring in a small DC-DC converter located at the first actuator on each façade. Only 1 W of power is required for the actuator to hold the louvers in place, and 2.5 W are required to move them, equating to about 25,000 kWh annually for the entire building.

The electrochromic glass also contributes to the total building load very minimally. At most, it will draw 3 kW of power if all of the installed glass is tinted to the maximum level at the same time, a scenario that will never occur. The current required to tint the glass will also be supplied via a DC-DC converter at approximately 4VDC.

Due to the wide range of efficiencies available for both AC and DC power sources, it is impossible to quantify an exact value for anticipated savings resulting from using DC over AC. However, 350 Mission's electrical design minimizes conversions between the two waveforms. It expands upon the idea of configuring localized DC grids within a building and creates a building-scale DC microgrid to complement the traditional AC distribution, from site generation through end use. This brings 350 Mission one step closer to the goal of [ZEROimpact].

Source Fuel vs. Site Fuel

When considering the impact of a building, it should not be viewed as an isolated system. It leaves an energy, waste, and emissions footprint beyond the building site itself. Reliance on the electric grid expands 350 Mission's boundary of influence to include the power plants and transmission lines of PG&E, as shown in Figure 38.



Figure 38. 350 Mission Boundary of Influence

On average, the process of utility generation and distribution is only 31% efficient in the United States. In other words, for every unit of energy reaching the building site, three units of primary fuel are consumed. This awareness of the environmental impact of source fuel was the catalyst behind the decision to use fuel cells for onsite energy generation to reduce dependence on the grid and minimize the overall building footprint.

Fuel Cell

Natural gas comprises approximately 25% of the primary fuel that feeds PG&E's electric utility grid, but there is also an extensive existing network of natural gas lines in downtown San Francisco available for use directly at the building site. Onsite natural gas mitigates the inefficiencies associated with the electric grid, as conservative estimates anticipate approximately 10% transmission losses. Like the boilers and service water heating in 350 Mission, the fuel cells use natural gas as their primary fuel. The fuel cell cycle is outlined in Figure 39.

Three 400 kW units, two DC and one AC, support the expected DC and AC building loads of 535 kW and 393 kW respectively. Two smaller DC fuel cells were chosen, first to allow for flexibility of future use with additional onsite DC energy generation and second to maximize efficiency. The additional capacity would be especially useful for an expansion of the serverbased virtual computing or added mechanical equipment. The maximum efficiency for these units occurs when operating around 220 kW output, so using two fuel cells to meet the expected DC power demand comes at no efficiency cost.



The standard output of the fuel cell is 480VAC power which directly feeds the AC switchgear. The other two fuel cells require a custom order to remove the inverter within the assembly, resulting in 380VDC output that feeds the DC switchgear and producing an efficiency increase by removing a conversion.

Under normal conditions, 350 Mission can operate free of the electric utility grid. In the event of an unexpected peak in demand power, the fuel cell output can be supplemented by the grid through paralleling switchgear. Also, problems with natural gas infrastructure are uncommon but not unprecedented, making this grid connection a necessary source of redundancy. Paralleling also allows electricity to be supplied back onto the grid if the fuel cells and onsite renewable sources are producing more energy than the building requires, and two-way metering ensures that 350 Mission is credited for this energy.

Using fuel cells rather than the utility grid saves about 1,326,000 kWh of primary energy each year, and they also produce heat that is recovered for use in the building's mechanical system. Approximately 343,563 kWh of recovered heat can be used to heat 350 Mission annually, directly reducing the fuel consumption of the natural gas boilers. When considering the electrical generation and recovered heat together, the fuel cells are 48% efficient as compared to the utility's 31%. Though the building's carbon footprint is not eliminated, as CO₂ is still a byproduct, its quantity is greatly reduced. The CO₂ and unused heat will be exhausted via a duct running through the core to the roof of 350 Mission.

The cost of the installation will be approximately \$7,000,000, but the capital cost is only \$1,000,000 as the system's size qualifies it for over \$6,000,000 in self-generation incentives from the federal government and PG&E. Using utility natural gas over electric will also save the building owner \$230,000 annually. More information on the fuel cell and calculations can be found in Appendix G.

Server Room

The building computing loads are supported primarily by a virtual desktop infrastructure. Excess space on the lobby mechanical platform was partitioned into a server room, housing the rack servers that provide the majority of the building's processing power. The servers are accessed by thin client desktops, which require less than 20% of the power of full-capacity desktops.

There are approximately 120 thin client desktops and 12 full-capacity desktops per office floor, included to accommodate employees with very heavy program and application uses. The servers were sized to accommodate medium to heavy computing needs on the thin clients.

Servers save substantial energy for two main reasons. First, they can run directly on 380VDC power, eliminating AC-DC conversion losses that occur in computer power supply units
and increasing efficiency by more than 15%. Second, they maximize processor utilization. Energy consumption and processing output in computers and servers are not linearly related, so underutilized or idle devices are consuming wasted energy that does not contribute to any real computing application. The servers in 350 Mission were sized adequately but not oversized, ensuring high processor utilization and energy savings.

Onsite server installation was chosen over cloud-based virtual computing because it offers the tenants of 350 Mission more security and flexibility in creating their own computing infrastructure, and again, considering an energy boundary beyond the building site, cloud-based virtualization simply moves the energy consumption to an offsite data center. Cloud-based computing can be implemented by future tenants if desired, simply by removing the servers.

This virtual server-based infrastructure is expected to save 56% in computing energy use annually. A detailed analysis of server sizing and specification and computing power and energy calculations and a graphic outlining data distribution can be found in Appendix H.

Emergency Power System

The building's emergency power is supplied by standby batteries to maximize the advantages of using DC distribution. The emergency loads consist of egress lighting and life safety mechanical equipment, such as smoke exhaust fans and fire pumps, and all are fed with 380VDC. The fire alarm system will run on the battery packs within the control panels in the event of an emergency.

The battery units consist of battery packs wired in series to achieve the high voltage distribution necessary to feed the emergency loads. Many of the emergency loads also operate on normal power during standard building operation. Therefore, the emergency panels are served by normal output from the DC switchgear, and the battery packs are placed in parallel. The output from the DC switchgear is always at a slightly higher voltage, so the batteries are never in use

until this normal voltage either stops or decreases substantially in the event of a utility outage or emergency. The building control system periodically verifies that the voltage of the batteries is adequate, and the battery packs replace the need for purchasing a generator and supplying and storing its fuel. This increases the reliability of the emergency system because there is no risk of interruption of the generator fuel supply.

Seismic Design

Lobby Lighting

One of the challenges with the design in the lobby was the conflict between the criteria of visually reducing the scale of the lobby and creating an earthquake-conscious design. The scale reduction was achieved through the use of suspended luminaires; however, these can be dangerous in earthquake scenarios. Neither criterion could be discarded as each was developed for a reason, one for occupant comfort and the other for occupant safety. In order to address both of these concerns, the initial conceptual design using suspended luminaires was maintained, and the design for the lobby follows the guidelines set forth by the Federal Emergency Management Agency (FEMA) and the California Department of General Services (DGS) for the support of pendant mounted light fixtures in earthquake-prone areas. As required by DGS, the design ensures that all luminaires can swing to 45 degrees without the risk of collision with another fixture, support cables, columns, or walls. The model shown in Figure 40 was used to define the swing area of each luminaire and aid in the design of the space. More information about how the design follows these guidelines can be found in Appendix I.



Figure 40. Isometric View of Lobby with Luminaire Swing Areas Defined

Dual Electrical Risers

As San Francisco is located in a seismic region, the electrical system was designed with an extra emphasis on safety and redundancy. In the event of an earthquake or other emergency, it is important for the emergency lighting and other important electrical loads to be maintained. While most buildings have a single set of electrical risers carrying power to the entire building, the electrical design for 350 Mission contains two sets of electrical risers, one being the bus duct located in the main electrical room and the other located in the electrical closet, as shown in Figure 41.



Multiple electrical risers have been utilized in other buildings in earthquake-prone areas, such as Taipei 101 in Taiwan.[6] The rooms are located on opposite sides of the core, decreasing the likelihood that risers located in both locations would be damaged in the event of an earthquake.



Figure 42. Isometric View of Dual Riser System

As shown in Figure 42, the electrical room contains the normal power electrical risers, both AC (blue) and DC (red), and a DC emergency riser. During normal building operation, the entire electrical load is served by the electrical room. If the utility fails during an emergency, the building will switch to battery power and feed the emergency loads, which are all on DC power, through the electrical room emergency riser.

If the electrical risers in the main electrical room are damaged, the building clearly will have undergone serious structural damage, and occupant safety during egress will be of paramount importance. In this situation, getting power to the emergency loads would be impossible with a traditional single riser. 350 Mission has a secondary emergency riser that serves the life safety loads. If the primary riser is damaged, an ATS switches the emergency battery feed to this secondary emergency riser, supplying power to the most vital building loads. All of the emergency loads are on DC power, and as a result, the electrical closet will only contain a DC riser.

Plug Load Controls

Like most modern office buildings, plug loads comprise more of the overall electrical energy use than any other component or system. Computers, electronics, and appliances that remain plugged in continue to draw small amounts of power, despite the fact that they might be in standby mode or even turned off. Since unplugging everything at the end of the day is impractical, plug load controls help remedy this wasted energy, which is sometimes called a "phantom load." Quantifying the savings from plug load controls is complex and involves many assumptions about future use.

In order to quantify these savings, the results of an extensive plug load control study conducted by the California Utilities Statewide Codes and Standards Team in conjunction with PG&E using prototype office spaces was used [13]. The study's recommended plug load control strategies are employed in 350 Mission, with similar energy savings expected.

As summarized in Table 12, time switch controls are used to open circuits during nonworking hours in order to achieve maximum energy savings. Occupancy sensors also supplement the time clock in some spaces to save energy during working hours when electronics are not in use. Despite potential energy savings, some electronics should always remain in at least a standby power mode, such as continuous-use devices, like refrigerators. Desktops are also considered non-controllable loads, since they might receive updates or be remotely accessed at any time, and VoIP phones must always be capable of receiving messages.

Plug Load	Control Strategy
Computer monitors	These devices operate on both time clock controls and occupancy sensors. There is
Open office task lighting	no threat of losing data if the device shuts off due to inactivity in the space. With 120
Audio/visual equipment	to save task lighting and computer monitor energy. AV equipment in conference
General use receptacles	rooms may go unused for long periods of time when the rooms are empty.
Printing, copying, and scanning equipment	Receptacles serving these loads operate solely on a time clock. Most kitchen appliances require operation throughout the work day, even when the kitchen is not
Kitchen Appliances	occupied, and copy room devices often receive signals when the room is empty.

Table 12, 350 Mission Plug Load Controls Summary

The intelligence behind the plug load system will rely on the DALI system and the established infrastructure of controls that are using for the office lighting. Controlling plug loads comes at a higher capital cost with more complex installation, as circuiting must be done such that loads with similar controls are included on the same circuits, but this quickly pays for itself through energy savings. As with any energy saving system, the occupants must be educated on how the system operates to maximize participation. This control strategy is expected to save 183,000 kWh annually, as summarized in Table 13.

	Table 13. Expected Plug Load Energy Savings									
	Plug Load Savings									
Large Offices	arge Offices 0.61 kwh / year / ft. ² Based on "large" (175,000 ft. ² office)									
350 Mission Area	300,000	ft. ²	Usable office space on 25 office floors							
Estimated Energy Savings	183,000	kwh / year	See plug load control section for description of control strategy							

The power plan is shown in Figure 43. Quadruplex receptacles are provided at workstations to provide power to the thin client computers. Other receptacles are located throughout the space to accommodate less consistent loads. Junction boxes in the ceiling show the locations of the DC power supply modules.



Figure 43. Office Floor Power Plan

The spreadsheet shown in Table 14 summarizes the connected, demand, and expected office receptacle loads.

		Table	e 14	. Of	fic	e Reo	cept	tacle	Lo	ad S	um	mar	y	
_			Qua	Maxi	mu	Conne	cted	Conne	ected	Dema	and	Expe	ted	
Туре	Location	Purpose	ntit V	m Po pe	wer r	flo	r per or	Build	r tor ling	Build	r tor ling	Dem Powe	and r for	Notes and Assumptions about Expected Demand Power
					G	eneral	Use F	Recepta	acles					4
Duplex	Column covers	General use	18	180	VA	3.24	kVA	81	kVA	45.5	kVA	4.55	kV	Assume 10% are in use at any given time
	Open office floor	1	1	1			ben C	тисе	1				1	Thin client deskton = 30W_LED backlit monitor =
	under desk	Thin client desktops,											kV	30W, full desktop = 175W (Max power) Assume
Quadruplex	partitions	computer monitors	66	360	VA	23.8	kVA	594	kVA	594	kVA	222	А	10% full desktop
	At each open office												kV	Assume that 50% of task lights will be at full
Hard-wired	desk	Task light	120	6.5	VA	U.78	KVA vible	19.5 Snace	KVA	19.5	KVA	12.19	A	output and 25% at hair output simultaneously
		Thin client desktops,					TOIC						kV	Thin client desktop = 40W, LED backlit monitor =
Duplex	Floor	computer monitors	6	180	VA	1.1	kVA	27	kVA	27	kVA	10.5	А	30W (Max power)
	1	Conorol uso of	<u> </u>	r	L:	arge Co	onfere	ence Ro	oom	r			LA.	Assume that EOM of conference reams are
Duplex	Walls	additional electronics	3	180	VA	0.5	kVA	13.5	kVA	11.8	kVA	5.88	A	simultaneously in use
													kV	Assume that 50% of conference rooms are
Duplex	Ceiling	Video projector	1	180	VA	0.2	kVA	4.5	kVA	7.25	kVA	3.63	А	simultaneously in use
Duralau	Class.	For use at central		100			1.3.7.6		1.3 / 6		1.3 / 6	4 50	kV	Assume that 50% of conference rooms are
Duplex	FIOOF	conference table	2	180	VA Sr	nall Co	nfere	nce Ro	oms	9	KVA	4.50	A	
		General use of											kV	Assume that 50% of conference rooms are
Duplex	Walls	additional electronics	4	180	VA	0.7	kVA	18	kVA	14	kVA	7	А	simultaneously in use
													kV	Assume that 50% of conference rooms are
Duplex	Ceiling	Video projector	2	180	VA	0.4	kVA	9	kVA	9.5	kVA	4.75	A	simultaneously in use
Quadruplex	Floor	conference table	2	360	VA	0.7	kVA	18	kVA	18	kVA	9	A	simultaneously in use
					Vi	deo Co	nfere	nce Ro	oms	-	1	-		· · · · · · · · · · · · · · · · · · ·
		Operation of TV and												TV, LCD = 60W, speakers = 30W Assume that
Duploy	Noar TV scroop	video conference		190		0.7	L\/A	10	L\/A	10	LA/A	2 22	kV	33% of video conference rooms are
Duplex	Near IV Screen	General use of	4	100	VA.	0.7	NVA	10	NVA	10	KVA	2.25	kV	Assume that 33% of video conference rooms are
Duplex	Adjoining wall	additional electronics	4	180	VA	0.7	kVA	18	kVA	14	kVA	4.62	А	simultaneously in use
	1			1		Inter	view	Rooms	5		1			
Duploy	W/5/	General use of	2	190		0.5	L\/A	12 5	L\/A	11.0	LA/A	2.25	kV	Assume that 20% of interview rooms are
Duplex	wan	electromes	5	100	VA.	Printer	/Cop	ier Roc	m	11.0		2.55		
		(1) laser printer, (1)												
	At equipment	inkjet multifunction											kV	Laser printer = 130W, Inkjet MFD = 26W Assume
Duplex	locations	printer	1	180	VA	0.2	kVA	4.5	kVA	4.5	kVA	2.34	A	60% of units are in use simultaneously
Duplex	current equipment	General purpose	2	180	VA	04	kVA	9	kVA	9	kVA	0.9	A	Assume 10% are simultaneously in use
Bupick	current equipment	recetacies for growth		No	rthw	vest an	d Sou	theast	Corri	dors		0.5	<u>, , , , , , , , , , , , , , , , , , , </u>	
	around building												kV	
Duplex	core	General use	4	180	VA	0.7	kVA	18	kVA	14	kVA	1.4	А	Assume 10% are simultaneously in use
Duploy	Entrance to elevator	TV's showing energy		100		0.4			L\/A	0.5	1.2/4	2	kV	$T_{\rm M}$ LCD = 60.04
Duplex	cornuor	use on onice noor	2	180	VA	0.4	Kitch	9 en	KVA	9.5	KVA	5	A	17, LCD = 6000
Duplex (special	At equipment												kV	Equipment on standby = 2W Assume 50% of
purpose) GFI	locations	Coffee maker	1	464	VA	0.5	kVA	11.6	kVA	11.6	kVA	5.59	А	coffee makers are on standby, 50% active
Duplex (special	At equipment												kV	Equipment on standby = 3W Assume 75% of
purpose) GFI	locations At aquinment	Microwave oven	1	1620	VA	1.6	kVA	40.5	kVA	40.5	kVA	11.39	A	microwaves are on standby, 25% active
Duplex GE	locations	Water dispenser	1	180	VA	0.2	kVA	45	kVA	45	kVA	0.65		75% of dispenser are on standby 25% active
Duplex (special	At equipment	Hot beverage											kV	Equipment on standby = 75W Assume 75% of
purpose) GFI	locations	dispenser	1	1650	VA	1.7	kVA	41.3	kVA	41.3	kVA	12.90	А	dispensers are on standby, 25% active
Duplex (special	At equipment												kV	
purpose) GFI	locations	Refrigerator	1	650	VA	0.7	KVA estre	16.3	κVΑ	16.3	IKVA	16.25	A	Always in use
Duplex GFI	Above sinks	Miscellaneous use	4	180	VA	0.7	kVA	18	kVA	14	kVA	0.70	A	Assume 5% are simultaneously in use
Spren Gri			UI	tility Sp	baces	s (Elect	rical,	Mecha	inical,	, Telecc	om)		<u></u>	
Duplex	Walls	Miscellaneous use	7	180	VA	1.3	kVA	31.5	kVA	20.8	kVA	1.04	kV	Assume 5% are simultaneously in use
	OFF	CE FLOORS TOTAL						Conne 1034	ected	Dema	and	Experies 241	ted	

Building Space Use Summary

The diagram shown in Figure 44 details the locations of the various equipment and system components and gives a clearer picture of how all of the various parts work together to create the final overall lighting and electrical system.



Figure 44. Building Equipment Summary

Chapter 7

Fire Alarm Design

The primary fire alarm control panel is located in the fire command room on the first floor of the lobby. This panel contains the logic of the fire alarm system by interfacing with the BACnet system's duct smoke detectors and receives input from smaller panels located on each level of the building. The fire alarm circuits run on 24VDC.



Figure 45. Office Floor – Fire Alarm Plan

As shown in the floor plan in Figure 45, two small control panels are located in the electrical room and systems closets on each floor. These are fed by 208Y/120VAC with integral rechargeable battery backup in accordance with National Fire Protection Association mandates.



Figure 46. Open Office and Circulation Speaker-Strobe Coverage

After receiving a signal from the alarm initiation devices, notification appliances shown in Figure 46 alert occupants to the potential emergency. Speaker-strobe devices are located in open spaces, corridors, and utility spaces, and their coverage is shown. Visual strobes are located in all of the conference rooms. Automatic door operators automatically close (but do not lock) the doors to the elevator lobby in the event of an emergency to discourage elevator use and prevent the spread of fire through the core.



Figure 47. Open Office and Circulation Smoke Detector Coverage Each panel has two 24VDC initiating device circuits that supply the smoke detectors and manual pull stations. The 20' radius smoke detector coverage of the open spaces and corridors is shown in Figure 47, and each separately partitioned space has its own dedicated smoke detector. Manual pull stations are located in the primary egress path at the entrances to the stairways. Stair vestibules contain rescue intercom stations for two-way communication with a central station to dispatch the fire department.

Chapter 8

Data/Telecommunications Design

The data and telecom infrastructure provides the flexibility for future building occupants to create a building area network (BAN) or multiple local area networks (LANs) to allow data sharing between network users. The servers providing computing power and the telecom equipment loads are served by the 380VDC distribution and converted using a highly efficient 380VDC-48VDC power supply designed for data and telecom applications.



Figure 48. Building Data Riser Schematic

Figure 48 shows a schematic of the building data system. At each floor, the data and

telecom services are supplied through a fiber patch panel and patch panel. Six hardwired access

panels provide WiFi, and open office workstations are equipped with a voice/data outlet for VoIP phones, as shown in the floor plan in Figure 49. Conference rooms have a TV outlet and voice/data outlet. TV outlets/TVs are also provided near the elevator lobby to make occupants aware of their monthly energy usage.



Figure 49. Office Floor – Data and Telecommunications Floor Plan

Chapter 9

LEED

Under the LEED 2009 for New Construction and Major Renovations Checklist, 350 Mission can achieve LEED Platinum Accreditation, accumulating 93 points out of a possible 110 points. Receiving Daylight & Views credits, along with other points associated with lighting and electrical design, contributed to achieving this level of certification. [12]



Figure 50. LEED Point Summary

Figure 50 summarizes the LEED points achieved in each of the seven categories. The

complete list of categories and points received is listed below:

Sustainable Sites (21/26 Points)

Prereq 1	Construction Activity Pollution Prevention	
Credit 1	Site Selection	1 Point
Credit 2	Development Density and Community Connectivity	5 Points
Credit 4.1	Alternative Transportation – Public Transportation Access	6 Points
Credit 4.2	Alternative Transportation – Bicycle Storage and Changing Rooms	1 Point

		77
Credit 4.3	Alternative Transportation – Low-Emitting and Fuel-Efficient Vehicles	3 Points
Credit 4.4	Alternative Transportation – Parking Capacity	2 Points
Credit 6.1	Stormwater Design – Quantity Control	1 Point
Credit 7.1	Heat Island Effect – Non-roof	1 Point
Credit 8	Light Pollution Reduction	1 Point
Water Effic	iency (10/10 Points)	
Prereq 1	Water Use Reduction – 20% Reduction	
Credit 1	Water Efficient Landscaping No Potable Water Use or Irrigation	4 Points
Credit 2	Innovative Wastewater Technologies	2 Points
Credit 3	Water Use Reduction Reduce by 40%	4 Points
Fnerov and	Atmosphere (31/35 Points)	
Prerea 1	Fundamental Commissioning of Building Energy Systems	
Prereg 2	Minimum Energy Performance	
Prereq 3	Fundamental Refrigerant Management	
Credit 1	Optimize Energy Performance Improve by 48%+ for New Buildings	19 Points
Credit 2	On-Site Renewable Energy 72% Renewable Energy	7 Points
Credit 3	Enhanced Commissioning	2 Points
Credit 5	Measurement and Verification	3 Points
Materials a	nd Resources (9/14 Points)	
Prereq 1	Storage and Collection of Recyclables	
Credit 2	Construction Waste Management 75% Recycled or Salvaged	2 Points
Credit 3	Materials Reuse Reuse 10%	2 Points
Credit 4	Recycled Content 20% of Materials	2 Points
Credit 5	Regional Materials	2 Points
Credit 7	Certified Wood	1 Point
Indoor Fnv	ironmental Quality (14/15 Points)	
Prereg 1	Minimum Indoor Air Quality Performance	1 Point
Prereq 2	Environmental Tobacco Smoke (ETS) Control	1 Point
Credit 1	Outdoor Air Delivery Monitoring	1 Point
Credit 2	Increased Ventilation	1 Point
Credit 3.1	Construction IAQ Management Plan – During Construction	1 Point
Credit 3.2	Construction IAQ Management Plan – Before Occupancy	1 Point
Credit 4.1	Low-Emitting Materials – Adhesives and Sealants	1 Point
Credit 4.2	Low-Emitting Materials – Paints and Coatings	1 Point
Credit 4.3	Low-Emitting Materials – Flooring Systems	1 Point
Credit 4.4	Low-Emitting Materials – Composite Wood and Agrifiber Products	1 Point
Credit 5	Indoor Chemical and Pollutant Source Control	1 Point
Credit 6.1	Controllability of Systems – Lighting	1 Point
Credit 6.2	Controllability of Systems – Thermal Comfort	1 Point
Credit 7.1	Thermal Comfort – Design	1 Point
Credit 7.2	Thermal Comfort – Verification	1 Point

	78
Daylight and Views - Views	1 Point
and Design Process (4/6 Points)	
Innovation in Design: Acoustics Pilot Credit	1 Point
Innovation in Design: Interior Lighting – Quality Pilot Credit	1 Point
Innovation in Design: Sustainable Wastewater Management Pilot Credit	1 Point
LEED Accredited Professional	1 Point
riority Credits (4/4 Points)	
Regional Priority: On-site Renewable Energy	1 Point
Regional Priority: Daylight & Views - Daylight	1 Point
Regional Priority: Innovative wastewater technologies	1 Point
Regional Priority: Water use reduction	1 Point
	Daylight and Views - Views and Design Process (4/6 Points) Innovation in Design: Acoustics Pilot Credit Innovation in Design: Interior Lighting – Quality Pilot Credit Innovation in Design: Sustainable Wastewater Management Pilot Credit LEED Accredited Professional Priority Credits (4/4 Points) Regional Priority: On-site Renewable Energy Regional Priority: Daylight & Views - Daylight Regional Priority: Innovative wastewater technologies Regional Priority: Water use reduction

Total LEED Points 93/110

Chapter 10

Conclusion

The underlying attitude of [ZEROimpact] guided the approach of the project through the four design emphases of [ZEROenergy], [ZEROinterruption], [ZEROwaste], and [ZEROemissions]. In conjunction with other building systems, the lighting and electrical system design effectively contributes to all four areas while remaining economically feasible. The approach has culminated in a design that is beneficial to the environment, building occupants, and owner.

Fuel savings due to the mechanical and electrical systems are summarized in Figure 51.



Figure 51. Baseline vs. Designed Site Fuel Consumption by Building Component

The lighting design features a daylighting and control system and energy efficient lighting that result in over 100,000 kWh of savings annually and a building LPD of 0.434 W/sf, as compared to the code-allowed value of 0.728 W/sf.

The innovative electrical system fully embraces DC distribution, using it to power computer servers, LED lighting, VFDs, motors, low voltage controls, and other devices. Virtual computing eliminates the need for full-sized desktop computers at every workstation, saving almost 600,000 kWh each year.

Fuel cells supply energy to the building and save over \$230,000 in energy costs annually by allowing the owner to purchase natural gas rather than electricity from the utility grid, and their exhaust heat is sufficient to cover the heating needs of the building 87% of the time.

Energy is generated via onsite and offsite solar arrays, as well as an onsite human wasteto-power converter. These systems combined generate 5,544,000 kWh annually, which is more than enough to cover the building's overall annual consumption of 5,264,570 kWh.



With its advanced mechanical and electrical systems, 350 Mission has a higher upfront cost than the baseline building meeting the code-minimum requirements, as shown in Figure 52.

Figure 52. Net Present Value of Mechanical and Electrical Proposed Design Compared to Baseline

However, through the profit accrued by selling the energy generated by onsite and offsite solutions back to the utility company, these advanced systems will pay back in 10.8 years, making them well worth the initial investment.

350 Mission adheres to the traditional definition of net-zero by returning as much energy to the grid as it consumes in a year, and it also meets the broader goals defined by **AEVITAS** by minimizing emissions and waste and by creating a design that responds to the earthquake-prone environment to ensure continuity of operation even after a seismic event.

The final building design successfully responds to the project requirements and achieves the project goals through the use of innovative and efficient design techniques.

Appendix A

Rejected Energy Generation Methods

Onsite Energy

 Table 15. Rejected Onsite Energy Generation Methods

Alternative	Reason(s)	Details
Energy	for	
Technology	Rejection	
Geothermal electrical generation	Feasibility, threat of induced seismicity	While geothermal heating is possible, ground water temperatures hot enough to power steam turbines for electricity generation require drilling more than 1 mile into the earth. This scale of drilling would not reasonably occur under a highrise in downtown San Francisco. Drilling at that scale for geothermal wells in a highly seismic region also runs the risk of induced seismic events, events that could be catastrophic in a highly developed area.
Wind	Building site	The average wind speed required for building-scale wind turbines is about 12 mph, and San Francisco's average wind speed is 7 mph. However, the effect of wind funneling through the downtown buildings also had to be considered. In general, tall buildings to the northwest of Market Street tend to obstruct and redirect the flow of wind, decreasing the downwind resource southeast of Market. In Figure 53, the building outlined in red is 35' taller than 350 Mission and only has potential on a portion of its roof. Even this potential is not present on the roof of 350 Mission, as it is blocked by the red building.[7]
PaveGen	Cost, lack of useful production	PaveGen floor tiles use piezoelectric polymers to convert kinetic energy in the form of footsteps to mechanical energy. This technology was explored due to the anticipated high foot traffic in the building lobby and circulation spaces and because it is highly renewable by harnessing the movement of occupants. While PaveGen is a unique feature, the energy generated is difficult to quantify based on its existing installations (several have been installed in past testing phases) and the initial cost is unreasonable for a large installation. Instead, PaveGen will be used as a teaching tool in the public art installation and not relied upon as a substantial source of energy.

Algae and Plant Biomass	Issue of scale, location	While algae and plant biomass has been successfully implemented in buildings, the scale of onsite biomass that could be achieved in an urban setting for a highrise would not provide enough electrical power to justify the additional costs and maintenance associated with it. Successful building installations of algae have taken place on sites with a great deal of sun exposure, which is necessary to cultivate the biomass. Instead of creating biomass fuels onsite, the goal is to utilize byproducts of occupancy, namely human waste, to create energy.
Municipal Waste to Power Converter	Inadequate volume of input materials	The city of San Francisco is on a mission to become the greenest city in America, with the ultimate goal of diverting 100% of its waste from landfills by the year 2020. The city is currently diverting about 80% of its waste due to composting and recycling programs. The conversion process takes non-recyclable and non-compostable waste and turns it into usable power through a gasification process. While this technology was found to be very useful, with the small amount of applicable waste produced by the 350 Mission, it is not worth the investment and will not produce a useful amount of power.

Offsite Energy

Table 16. Rejected Offsite Energy Generation Methods

Alternative Energy Technology	Reason(s) for Rejection	Details
Geothermal electrical generation	Cost, issue of scale, procurement of land	San Francisco lies within California's "Pacific Ring of Fire," which makes it a prime location for geothermal energy generation. PG&E receives some of its utility capacity from The Geysers, a large complex of geothermal plants located 72 miles north of San Francisco. Creating a geothermal electrical generation site to offset the energy usage of one building becomes impractical due to the cost and issues of scale associated with it.
Tidal energy	Infancy of technology, lack of suitable locations, permits	San Francisco Bay was identified as a potential site for tidal energy because it has strong currents, minimal turbulent flow, and areas with appropriate depths. An extensive study was conducted jointly by PG&E, the City of San Francisco, and Golden Gate Energy Company on the potential use of tidal power as a renewable energy source in San Francisco Bay. The study found that the only locations in the generally shallow bay that were deep enough for tidal turbines and had high enough water velocity to move them were located in shipping lanes. The bathymetry can be seen in Figure 54. As of May 2011, after pumping millions of dollars into the study, PG&E abandoned its efforts, saying that tidal power is still too new for practical use in the Bay.[5]
Wind	Issue of scale, procurement of land	Most wind energy in California is concentrated at three utility-scale wind farms. The closest one is located at Altamont Pass, lying 40 miles east of San Francisco. The use of wind energy has seen large increases in California over the past decade, and offshore wind has even been explored by the city of San Francisco. However, much like geothermal electrical generation, creating a large-scale wind farm to offset the electrical use of one building is an ambitious pursuit. Not to mention, PG&E already uses the wind energy at Altamont Pass as one of its renewable sources.

Appendix B

Onsite and Offsite Energy

Onsite Solar

Table 17. Onsite Solar Costs								
	Cost							
Solar Panels	\$360,000							
Table 18. Onsite Solar In	come/Incentives							
	Amount							
Incentives	\$108,000							
Annual energy generation	194,144 kWh							
Annual Income	\$20.400							

With the minimum 30% incentives, the array will cost \$3,580,500 and will pay back in

12.4 years. With 50% covered by incentives, this payback period is reduced to 8.8 years.

			Ons	ite Solar Po	tential Anal	ysis			
Area repres	ented by ea	ch point	3.861225	ft ²	=	0.358719	m²		
	Sensor Poin	t	Sen	sor Orienta	tion	Annual	Daily	Annual	Daily
х	у	z	x	у	z	kwh/m2	kwh/m2	kwh	kwh
-92.9875	-0.27729	440.1	0	0	1	663.74	1.82	238.10	0.65
-92.9875	1.687739	440.1	0	0	1	789.08	2.16	283.06	0.78
-91.0225	-2.24232	440.1	0	0	1	713.62	1.96	255.99	0.70
-91.0225	-0.27729	440.1	0	0	1	946.03	2.59	339.36	0.93
87.79528	3.652769	440.1	0	0	1	1078.48	2.95	386.87	1.06
89.76031	-0.27729	440.1	0	0	1	1058.49	2.90	379.70	1.04
89.76031	1.687739	440.1	0	0	1	1065.26	2.92	382.13	1.05
#	#	nodegroup	00				Sum	1769374	
#	0	0	1				Efficiency	265406.03	
#	-0.7071	0.7071	0				Derate	204362.65	
#	-0.7071	-0.7071	0				Walkways	194144.51	
#	1.965								
#	1.965								
#	-1								
#									
#	4278								

 Table 19. Portion of Onsite Solar Array Analysis Spreadsheet

The spreadsheet shown in Table 19 was used to calculate the potential for onsite solar harvesting. A simulation was conducted using Diva for Rhino, and the output was imported into Excel for analysis. The data has been cropped, but 4278 calculation points were used with each representing a 1.965' x 1.965' area of the roof. Solar radiation numbers were converted to kWh values and summed, and efficiency values were applied to get the final number outlined in red.

Human Waste – to – Power

10 dry tons generates 18,868 kWh \rightarrow 1 pound generates 0.93 kWh

The average person will generate about 0.25 dry pounds per day.

$$0.25 \frac{dry \ pounds}{person} * 5000 \ people = 1250 \ dry \ pounds$$
$$1250 \ dry \ lbs * 0.93 \ kWh = 1163 \frac{kWh}{day}$$
$$1163 \frac{kWh}{day} * 250 \frac{working \ days}{year} = 290,625 \frac{kWh}{year}$$

Simple Payback

$$\$0.13 \text{ per } kWh \ast 290,625 \frac{kWh}{year} = \$37,781 \text{ annually}$$
$$\$1,000,000 \text{ amproximate initial soft}$$

$$\frac{\$1,000,000 \text{ approximate initial cost}}{\$37,781 \text{ per year}} = 26 \text{ years}$$

Offsite Solar Array

After the site was selected, the National Renewable Energy Laboratory's (NREL)

PVWatts calculator to determine the required array size and its generation potential, seen in Figure 55. The PG&E power purchase agreement shown in Figure 56 lists the sell-back amount

as \$0.10509/kWh, assuming a 20-year contract and building completion in 2016.

Station Identif	fication		F	Results	
Cell ID:	0176359	Manth	Solar	AC	Energy
State:	California		(kWh/m ² /day)	Energy (kWh)	Value (S)
Latitude:	34.9 ° N	1	5.27	348266	50031.89
Longitude:	118.1 ° W	2	5.98	358230	51463.32
PV System Specification	ons	3	6.78	440047	63217.15
DC Rating:	3000.0 kW	4	7.24	450080	64658.49
DC to AC Derate Factor:	0.750	5	7.52	468484	67302.41
AC Rating:	2250.0 kW	6	7.71	452164	64957.88
Array Type:	Fixed Tilt	7	7.62	454446	65285.71
Array Tilt.	34.9 °	8	7.88	471687	67762.56
Array Azimuth:	180.0 °	9	7.56	447211	64246.33
Energy Specifications		10	7.09	448603	64446.31
Cost of Electricity:	14.4 ¢/kWh	11	6.12	386421	55513.24
	alleri C Compensa	12	5.13	333546	47917.22
		Year	6.83	5059186	726802.6

Figure 55. Offsite Solar Panel Analysis

Pacific C San Fran U 39	Gas and Electric Company ncisco, California	Cancelling	Revised Original	Cal. P.U.C. Sheet Cal. P.U.C. Sheet	No. 28701-E No. 28031-E		
	Sheet 3						
SPECIAL CONDTIONS: (cont'd)	6. The Market Pr the Commissi 2011.	ice Referent (MPR on approved in Re	Referent (MPR) is stated in the table below, wh approved in Resolution E-4442, effective Decen				
	Adopte	ed 2011 Market Pr (Nominal - dollars	<u>ice Referents</u> /kWh)		(N) 		
	Resource Type	10-Year	15-Year	20-Year			
	2012 Baseload MPR	0.07688	0.08352	0.08956	i		
	2013 Baseload MPR	0.08103	0.08775	0.09375			
	2014 Baseload MPR	0.08454	0.09151	0.09756			
	2015 Baseload MPR	0.08804	0.09520	0.10132	_		
	2016 Baseload MPR	0.09156	0.09883	0.10509			
	2017 Baseload MPR	0.09488	0.10223	0.10859	İ		
Advice Letter No: Decision No. 3C0	3965-E-A Bi V Reg	Issued by ian K. Cherry lice President ulatory Relations	D E R	ate Filed ffective esolution No.	February 10, 2012 January 3, 2012 E-4442		

Figure 56. PG&E Renewable Energy Credit Purchase Price



Figure 57. Offsite Solar Array Location

The array is 3000kW and covers 3.5 acres of the 10 acre site shown in Figure 57. It costs approximately \$5,115,000, but at least 30% of this is covered by federal incentives, as shown in Figure 58. Additional incentives from PG&E are possible, but they require an application and waiting list and are not definite. 30% was assumed as a minimum.

Table 20. Offsite Solar Costs									
	Cost								
Land	\$13,000								
Solar Panels	\$5,115,000								
Table 21. Offsite Solar Income/Incentives									
Table 21. Offsite Solar Incon	ne/Incentives								
Table 21. Offsite Solar Incon	ne/Incentives Amount								
Table 21. Offsite Solar Incon Incentives	Amount \$1,534,500								
Table 21. Offsite Solar Incon Incentives Annual energy generation	e/Incentives Amount \$1,534,500 5,059,186 kWh								

With the minimum 30% incentives, the array will cost \$3,580,500 and will pay back in

6.7 years. With 50% covered by incentives, this payback period is reduced to 4.8 years.

DSIRE Database of State Incenti	TM ives for Renewa	bles & Efficiency		-			energy Efficiency & enewable Energy				
Home	Glossary	Links	FAQs	Contact	About						
DSIRE		FEDERAL Incentives/Policie	s for Ren	ewables & Ef	fficiency		Printable Version				
solar policy information											
Resources	Business Ene	ergy Investment Ta	ax Credit	(ITC)			[] Like < 76				
RPS Data	Last DSIRE Review	v: 01/03/2013									
Summary Maps		Stat	e: Federal								
Summary Tables		Incentive Typ	e: Corporat	e Tax Credit							
Library	Eligible Renew	able/Other Technologie	Solar Wa Process Geothern	ter Heat, Solar S Heat, Photovolta nal Electric, Fuel	ipace Heat, Solar ics, Landfill Gas, Cells, Geotherm	Thermal Ele Wind, Bioma al Heat Pum	ectric, Solar Thermal ass, Hydroelectric, ips, Municipal Solid akinatia Rowar (i a				
What's New? Search			Flowing V Wave En Microturb	Nater), Anaerobi ergy, Ocean The ines, Geotherma	c Digestion, Sma rmal, Fuel Cells u al Direct-Use	II Hydroelect Ising Renew	ric, Tidal Energy, /able Fuels,				
		Applicable Sector	s: Commer	cial, Industrial, U	Itility, Agricultural						
		Amour	t: 30% for s 10% for <u>c</u>	olar, fuel cells, s jeothermal, micr	small wind and P1 oturbines and CH	FC-eligible to IP*	echnologies;*				
		Maximum Incentiv	# Fuel cells: \$1,500 per 0.5 kW Microturbines: \$200 per kW Small wind turbines placed in service 10/4/08 - 12/31/08: \$4,000 Small wind turbines placed in service after 12/31/08: no limit All other eligible technologies: no limit								
		Eligible System Siz	e: Small win wind)* Fuel cells Microturb CHP: 50 Marine au	nd turbines: 100 s: 0.5 kW or grea ines: 2 MW or le MW or less* nd Hydrokinetic:	KW or less (exceț ter ss 150 KW or greatei	ot unlimited f	for PTC-eligible I by PTC eligibility)				
	E	quipment Requirement	s: Fuel cells efficiency	s, microturbines criteria	and CHP system	s must mee	t specific energy-				

Figure 58. Federal Incentives for Renewable Energy

Appendix C

Facade



Figure 59. Detailed Façade Section

Electrochromic Glass Cost Analysis

Table 22. Electrochromic Glass Cost Analysis									
Traditional Windows/Shades	Price	SF value (5'x8' windows)							
Low e, double pane glass	\$40-55/sf	\$40							
Shade fabric	\$28/sf	\$28							
Automatic shade motor	\$370 per unit	\$2.50							
Total		\$70.50							
Electrochromic Glass									
Glass	\$50-65/sf	\$65							
Total		\$65							

Cost data for this analysis was drawn from two sources: numbers for the traditional solution are from a Lutron cost comparison study [16] (summary shown in Table 23) and the electrochromic glass numbers are from the Sage Glass cost data sheet shown in Figure 60. If a price range was given, the lower numbers were used for the traditional solution and the higher numbers were used for the electrochromic glass.

These numbers are for materials alone; they do not include any labor costs. However, with traditional shades, there are labor costs for both the window installation and shade installation. With electrochromic glass, installations are hardly more complex than installing normal glass, and there is no additional shade installation.

			Qty	Total Price (USD)
Labor	Window Treatment	Administrative Charges	-	\$1,950.00
	Contractor	Keypad Cable Labor	-	\$400.00
		Shades Installation and	-	\$11,518.00
		Programming		
	Electricical Contractor	Line voltage wiring and circuit	-	\$10,172.19
		installation		
	Total Labor	\$24,040.19		
Wiring	Breakers & Electrical	20 A Breakers	6	\$157.15
	Materials	Miscellaneous Materials	-	\$2,099.59
	Cable (Qty. in feet)	#12/3 MC Cable (Shades Wiring)	2300	\$3,878.69
		#12/2 MC Cable (Breaker Wiring)	300	\$301.34
		Low Voltage 4 Conductor	400	\$193.60
		Keypad Cable		
	Total Wiring	\$6,630.37		
Components	Shades, Brackets and	Open Office Sheer Shade Pairs	17	\$18,464.15
	Lineals	Conference Rooms & Executive	6	\$6,950.94
		Office Dual Shade Pairs		
	Keypads	Group A, B, A+B Keypads	4	\$369.81
	Power and Control	6	\$2,207.55	
	Total Components	\$27,992.45		
Total Installed	Cost			\$58,663.01

Table 23. Lutro	Cost	Comparison	Study -	- Price	Summarv



Figure 60. Electrochromic Glass Cost Comparison – Sage Electronics

The cost comparison prices shown in Table 23 are for a line voltage AC shading system. The windows are the same size as those found in 350 Mission. The "per square foot" numbers were found by dividing the total price by the quantity shown in the table. This was then divided by the area of each shade represented by that number. For shade material, this was the area of one shade (5' x 8'). For motors, this was the area of four shades, as the Lutron study assumed four shades per controller. Only the glass, shade fabric, and motors were included in the study as the controls, wiring, etc. were assumed to be comparable for the two scenarios.

Appendix D



Urban Daylighting Study







							750	590	590	750		3400	865	902	1106						
							750	629	629	750		3400	802	839	1126						
	2181	337	386	671					750	655	655	750		3400	800	822	109		1966	874	606
	2181 2	363	412	697			750	655	655	750		3400 3	767	789	L076 1		1966 1	840	875	170 1	
	2181 2	363	412	687			750	655	655	750		3400 3	715	737	1011		: 9961	846	881	1170	
	2181 2	323	372	639			750	622	626	750		3400 3	715	737	1004		1966	793	828	1117 :	
	2181	310	373	661			750	622	622	750		3400	750	764	1031		1966	726	774	1063	
	2181	390	453	661			750	651	651	745		3400	718	732	1008		1966	666	728	1003	
	2181	390	453	661			750	628	628	734		3400	757	784	1047		1966	616	678	953	
	2181	420	461	692			750	568	568	725		3400	787	814	1086		1966	627	675	926	
	2181	443	484	680			750	531	531	722		3400	748	775	1047		1966	600	641	891	
	2181	443	484	680			750	531	531	720		3400	668	731	1052		1966	610	631	899	
	2181	475	516	712			750	446	446	708		3400	694	757	1078		1966	610	631	893	
	2181	466	544	711			750	421	421	700		3400	694	777	1086		1966	525	546	808	
ct sun	2181	430	544	715		ct sun)	750	367	367	695	ct sun)	3400	694	762	1093	ct sun)	1966	578	599	852	
of dire	2181	402	569	703		of dire	750	367	379	693	of dire	3400	720	788	1119	of dire	1966	587	608	861	
(hours	2181	402	549	703		hours	750	345	357	693	(hours	3400	687	765	1151	hours	1966	551	572	825	
çade	2181	436	555	989		çade (750	345	357	299	çade	3400	687	765	1159	ade (1966	584	605	858	
st Fa	2181	412	531	691		st Fa	750	337	349	627	st Fa	3400	687	765	1159	st Fa	1966	561	630	838	
thwe	2181	412	531	602		rthea	750	255	326	625	thwe	3400	202	<u>769</u>	1211	uthea	1966	909	675	883	
Nor	2181	431	550	734		No	750	255	326	625	Sou	3400	751	815	1243	Sol	1966	592	675	883	
	2181	431	550	2775			750	232	303	625		3400	713	777	1252		1966	589	672	871	
	2181	383	479	756			750	201	282	625		3400	685	749	1224		1966	607	690	843	
	2181	383	479	761			750	235	323	909		3400	685	749	1233		1966	658	728	894	
	2181	383	479	804			750	201	305	909		3400	693	757	1232		1966	692	729	872	
	2181	383	479	804			750	201	305	578		3400	725	789	1264		1966	725	762	905	
	2181	361	421	774			750	210	326	549		3400	739	803	1308		1966	749	786	870	
	2181	445	445	774			750	171	306	524		3400	762	826	1331		1966	782	819	903	
	2181	434	434	763			750	145	280	515		3400	793	857	1362		1966	775	812	896	
	2181	434	434	763			750	145	280	510		3400	793	857	1352		1966	775	812	896	
	2181	434	434	740			750	145	305	507		3400	879	943	1421		1966	862	899	963	
	2181	403	403	740			750	145	305	453		3400	854	918	1381		1966	895	932	966	
	2181	379	379	714			750	145	305	450		3400	854	918	1395		1966	880	917	981	
	Isolated	Floor 5	Floor 18	Floor 30			Isolated	Floor 5	Floor 18	Floor 30		Isolated	Floor 5	Floor 18	Floor 30		Isolated	Floor 5	Floor 18	Floor 30	

Table 28. Summary of Annual Direct Sun Hours
Appendix E

Lighting Design

Luminaire Schedule

The luminaire selection process was detailed and thorough. All options were assessed with efficacy as one of the most important criteria. The luminaire schedule in its entirety is shown on the following two pages.

							LUMINAIRE S	CHEDULE							
Luminaire Symbol	Image	Luminaire Type	Manufacturer and Series	Light Source	Correlated Color Temperature (K)	Color Rendering Index (CRI)	Wattage [W] at Full Output	Initial Lumens [Im] (lumen package)	Luminaire Efficacy [1m/W]	Luminaire Efficiency	Voltage	Mounting	Height into Plenum [inches]	Notes	Lumen Maintenance
C	H.	1" × 7.6" LED undercabinet strip	Feelux Diva 2	LED	4000	> 80	2.4	146	60.8		24 VDC	Surface- mounted		Square diffuser	L ₇₀ at 40,000
DA	S.	, 6" x 6" downlight	Gotham EVO	LED	4100	83	20.0	1125	56.3		24VDC	Recessed	6 3/4	O pen	L ₇₀ at 50,000
DB	S.	6" x 6" downlight	Gotham EVO	LED	4100	83	26.3	1590	60.5		24VDC	Recessed	6 3/4	Open	L ₇₀ at 50,000
DC	4	6" x 6" downlight	Gotham EVO	LED	4100	83	33.6	2150	64.0		24 VDC	Recessed	6 3/4	O pen	L ₇₀ at 50,000
DD	\$	4" × 4" downlight	Gotham EVO	LED	4100	8	20.0	1016	50.8		24VDC	Recessed	6 3/4	O pen	L ₇₀ at 50,000
11		1-lamp i ndustrial strip	Philips Day- Brite	F32T8	4100	06	34.0	2900	72.5	85.0%	24 VDC	Surface- mounted		O pen	-
12	Help	2-lamp industrial strip	Philips Day- Brite	F32T8	4100	06	67.0	5800	71.0	82.0%	24VDC	Surface- mounted	1	Open	1
112		12' x 4" linear	Axis Beam 4	LED	4000	> 80	46.2	4800	104.0		24 VDC	Recessed	4 3/4	Lensed	L ₇₀ at 50,000
L4		4' x 4" linear	Axis Beam 4	LED	4000	> 80	15.4	1600	104.0	1	24VDC	Recessed	4 3/4	Lensed	L ₇₀ at 50,000
Σ	-~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	Monorail mounted, aimable LED MR16 head	LBL Lighting Orbit Swivel	LED	4000	80	6.0	360	60.0	1	120VAC	Monorail	ı.	MR16 LED lamp	L ₇₀ at 30,000
0	\bigwedge	Adjus table task light	Koncept Z-Bar Mini	LED	4500	85	6.5	230	53.0	i.	120VAC	Desk- braced	i.	Lensed	L ₇₀ at 50,000

Table 29. Luminaire Schedule

Lumen Maintenance	L ₇₀ at 50,000	r	L ₇₀ at 50,000	L ₇₀ at 50,000	ı						
Notes	Lensed, configured into squares of 4 fixtures	Lens ed	Lens ed	Lens ed	Double or single faced with chevrons as indicated on plan						
Height into Plenum [inches]	T	,	ı	ı	ı	ı	ı	ı	3 7/8	3 7/8	ı
Mounting	Pendant	Surface- mounted	Recessed	Recessed	Ceiling mounted						
Voltage	24VDC	24VDC	24VDC	24VDC	24VDC						
Luminaire Efficiency		T						75.7%			
Luminaire Efficacy [Im/W]	104.0	104.0	100.6	93.4	104.0	104.0	102.0	65.5	6.99.3	93.1	ı
Initial Lumens [Im] (lumen package)	1200	1600	2000	3000	2400 up/ 2400 down	2400 up/ 3200 down	2400 up/ 4000 down	5800	2500	4400	ı
Wattage [W] at Full Output	11.0	14.7	19.0	30.7	22.0	25.7	30.0	67.0	25.2	47.3	3.5
Color Rendering Index (CRI)	> 80	> 80	> 80	> 80	> 80	> 80	> 80	06	> 80	> 80	1
Correlated Col or Temperature (K)	4000	4000	4000	4000	4000	4000	4000	4100	4000	4000	ı
Light Source	LED	F32T8	LED	LED	LED						
Manufacturer and Series	Axis Beam 4	Philips Day- Brite	Axis Day 2x2	Axis Day 2x2	Philips Chloride						
Luminaire Type	4' x 4" linear direct pendant	8' x 4" linear direct/indirect pendant	8' x 4" linear direct/indirect pendant	8' x 4" linear direct/indirect pendant	2-lamp stairwell	2' x 2' troffer	2' x 2' troffer	Edge-lit green LED exit sign			
Image											EXIT
Luminaire Symbol	PDA	PDB	PDC	DDD	PUA	PUB	PUC	ST	TA	E E	X1

Lobby Lighting Design

The lobby lighting layout in Figure 61 shows the suspension lengths of the decorative pendant squares, as well as the locations of the recessed, monorail mounted, and undercounter luminaires. Creative solutions were required due to the scale and layout of the space.



Figure 61. Lobby Lighting Plan



Figure 62. Lobby Pseudocolor Rendering

The pseudocolor rendering in Figure 62 shows the illuminance levels in the lobby,

designed to meet the criteria defined by IES requirements.

Most of the circulation areas are at 10 fc, shown by the green. The reception desk has higher illuminance levels to accommodate reading and writing.

Additional renderings of the lobby space are shown in Figures 63 and 64.



Figure 63. Lobby Rendering with View of Public Art Wall



Figure 64. Day and Nighttime Views of Lobby Lighting

Office Lighting Design

The office lighting is shown in Figure 65, with the exception of the task lighting located at each workstation. Exit signs are provided to mark the paths of egress, and emergency lighting provides 1 fc for egress circulation in the event of a power outage.



Figure 65. Office Floor Lighting Plan



Figure 66. Office Pseudocolor Rendering

Figure 66 shows a visual representation of the office illuminance levels due to electric lighting, designed to meet IES requirements.

Most of the circulation areas are at 10 fc, shown by the light blue.

The circulation areas around the desks are only at about 15 fc, with the additional

illuminance on the workplane being supplied by task lighting.

The flex area, in the absence of task lighting, has an even distribution of 30 fc across the

space.

Building Lighting Power Densities

	Table	SU. Space by S	Jace Eighting	I Ower Dells	ity Analysis		
	_		Code LPD	Code LPD with	Allowable Watts	Watts as	LPD as Designed
Space	Total Area [ft. ²]	Code Category	[\\\//f+ ²]	CalGreen		Designed [W]	[\\\//f+ ²]
			[00/10.]	Reduction (15%)	[**]	pesigned [W]	[•••/10.]
			Typical Office Flo	oor	-		
Open Office DC	5600	Office (>250 ft. ²)	0.9	0.77	4284.0	2166	0.39
Flexible Space	1100	Office (>250 ft. ²)	0.9	0.77	841.5	709.5	0.65
Break/Dining	1040	Dining	1.1	0.94	972.4	151.2	0.15
		Kitchen/Food					
Kitchen	100	preparation	1.6	1.36	136.0	100.8	1.01
Large Conference	600	Conference	1.4	1.19	714.0	277.2	0.46
(2) Small Conference	455	Conference	1.4	1.19	541.5	361.2	0.79
(4) Video Conference	405	Office (<250 ft.2)	1.1	0.94	378.7	378.4	0.93
(3) Interview Room	205	Office (<250 ft.2)	1.1	0.94	191.7	151.2	0.74
Printer/Copy	92	Support	0.6	0.51	46.9	25.2	0.27
Southwest Corridor	620	Corridor	0.6	0.51	316.2	120	0.19
Southeast Corridor	500	Corridor	0.6	0.51	255.0	120	0.24
Northwest Corridor	1025	Corridor	0.6	0.51	522.8	400	0.39
Flevator Jobby	400	Lobby/Waiting Area	1.1	0.94	374.0	105.2	0.26
Men's Restroom	200	Restroom	0.6	0.51	102.0	30.8	0.15
Women's Restroom	205	Restroom	0.6	0.51	104.6	30.8	0.15
(2) Stair and Vestibule	300	Stair	0.6	0.51	153.0	134	0.15
Service Lobby	75	Support	0.0	0.51	38.3	67	0.15
Electrical and Electrical		Support	0.0	0.51	50.5		0.05
Closet	80	Electrical room	0.7	0.60	47.6	68	0.85
Telecom and Telecom							
Closet	50	Telephone room	0.7	0.60	29.8	34	0.68
Mechanical	125	Mechanical room	0.7	0.60	252.0	268	0.63
Mechanica	423	Wechanicariooni	Lobby	0.00	232.3	208	0.03
General Illumination	5250	Lobby	11	0.94	5010.7	15/15 6	0.29
Potail Area	033	Potail	1.1	1.24	1252.0	1343.0	1.06
Fosturo Stairc	922	Stair	1.0	1.30	1255.9	373.0	1.00
Flavetaalabbu	330		0.0	0.51	204.0	10.3	0.02
Vestibule	383	Lobby/Waiting Area	1.1	0.94	358.1	200	0.52
Perception Dock	190	Office	1.1	0.94	165.5	100	0.82
Reception Desk	212 55 ft lana		0.9	0.77	162.2	102.0	0.34
reature Art Wall	55111011g	Wall Display	3.5	2.975	105.0	105.0	2.97
Destaurant Dising	2800	Disise	s (Assume design	utilizes maximum	2552.0		
Restaurant Dining	5800	Vitchon	1.1	1.36	5555.0	-	-
Restaurant Ritchen	120	Restran	1.6	1.30	660.0	-	-
Restaurant Restrooms	120	Ci-d	0.6	0.51	01.2	-	-
Restaurant Corridor	460	Corridor	0.6	0.51	234.6		
Lobby Support Space	1700	Support	0.6	0.51	612.0		
Locker rooms below grade	1200		0.6	0.51	612.0 525.5		-
Starrs below grade	1050	Stall	0.6	0.51	535.5		
Elevator Lobby below	800	Lobby/Waiting Area	1.1	0.94	748.0		
grade	10000	D 1:		0.17	105.5.4		
Parking Garage Parking	10920	Parking area	0.2	0.1/	1856.4	-	-
Parking Garage Ramps	26800	Parking ramps	0.6	0.51	13668.0		
Mechanical penthouse	5730	Mechanical room	0.7	0.60	3409.4	-	-
and below grade spaces							
Electrical below grade	2300	Electrical room	0.7	0.60	1368.5	-	-
spaces							
leicom Room below	600	Telephone room	0.7	0.60	357.0		
grade							
Below grade support							
spaces (water storage,	2875	Support	0.6	0.51	1466.3	-	-
pump room)							
Below grade storage	3650	Storage	0.6	0.51	1861.5		

Т	able	31.I	Lightin	g	Power	Den	sity	Load	Su	mmary	

	Lighting Power	Summary			Note about Expected Load
Total Connected DC Load [kW]	Total Connected AC Load [kW]	Total Expected DC Load [kW]	Total Expected AC Load [kW]	Apply a diversity fac	tor of 0.10 to all support, storage, electrical, mechanical,
156.2	20.5	138.0	20.5	simultaneously. The	e lighting in these spaces is controlled by occupancy
Total Lighting	g LPD	0.434	W/ft ²	sensors.	
	Lighting Energy	Summary	_		Note about Energy Calculations
Connected DC Energy Use [kwh]	Connected AC Energy Use [kwh]	Expected DC Energy Use [kwh]	Expected AC Energy Use [kwh]	Energy calculation u of use per workday,	ise assumes maximum light output (no dimming), 12 hours 250 workdays per year, and 5 hours of use on 10
505,314	62,282	454,273	62,282	hours, 365 days a ye hours a day, 360 da	ear, the restuarant and retail is considered to be in use 14 ys of the year. Parking areas are in use 16 hours a day.
	·	·	·		
	Lighting Comparis	on to Maximum LPD (Baseline)		
	Connected Load	Expected Load [kW]	Connected	Expected Energy	
As Designed	176.7	158.5	567.596	516,554	
Allowable by Code	296.3	278.6	763,259	718,342	
Baseline Reduction	119.6	120.2	195.663	201.788	

Appendix F

AC/DC Distribution

Table 32 summarizes the required conversions for each equipment type.

	Table 32. AC/DC Required	d Cor	iversion Summary
	DC DISTRIB	UTION	4
	INPU	т	
	DC FUEL CELL		
2001/00	ONSITE PHOTOVOLTAICS	l	NO CONVERSIONS
380000	HUMAN WASTE TO POWER		
	BACKUP UTILITY ELECTRIC	VIA	UTILITY XFMR AND RECTIFIER
	OUTP	UT	
	380VDC BUILD)ING RI	ISER
380VDC	MECHANICAL VFDS, MOTORS		NO CONVERSIONS
48\/DC	RACK SERVERS		
48VDC	DATA/TELECOM POWER SUPPLIES	VIA	
	LIGHTING		
241/00	DALI CONTROL POWER SUPPLY	VIA	380VDC TO 24VDC
24VDC	LOW VOLTAGE DEVICES		
	FAÇADE ACTUATORS	VIA	380VDC TO 24VDC CONVERTER
<4VDC	ELECTROCHROMIC GLASS	VIA	380VDC TO <4VDC CONVERTER
480VAC			
		JING K	ISER
			480∆ TO 208Y/120V
208Y/120	DESKTOPS, MONITORS	VIA	STEP-DOWN TRANSFORMER &
VAC	TASK AND RETAIL LIGHTING	4	
	FIRE ALARM CONTROL PANELS	1 1	DRIVER AC-DC RECTIFIERS

The schematic in Figure 67 details the building's AC and DC distribution systems and their associated loads. All DC equipment and components are shown in blue, AC in green, and natural gas-powered equipment is shown in red. The distribution systems work together to provide a balance between efficient and cost effective electrical design.



Figure 67. Load Classification Schematic

109

		380VD	C Distribu	tion						24VDC Di	stribution	1				
Circuit	Load Type	Max Load [A]	Actual Load [A]	Breaker on Panel [A]	Max Distance	V _{drop} Panel - PSM	PSM	Load [VA]	Load [A]	Channel	Load [VA]	Load [A]	Max Dist.	V _{drop} PSM - Luminaire	Max Total Branch Circuit V _{drop}	
										1	94.6	3.9	24	1.4%		
										2	94.6	3.9	24	1.4%		
										3	94.6	3.9	16	0.7%		
	Lighting.						1	662.2	27.6	4	47.3	2.0	12	0.3%		
1	controls	4.00	1.87	15	64	0.2%	(Flex)	00212	2.7.0	5	47.3	2.0	12	0.3%	1.6%	
							(6	94.6	3.9	16	0.7%		
										7	94.6	3.9	24	1.4%		
								/7 3	2.0	8 0 E	94.6	3.9	24	1.4%		
								47.5	2.0	1	47.3	1.7	56	1.3%		
										2	40	1.7	56	1.3%		
										3	92.4	3.9	47	2.6%		
										4	92.4	3.9	47	2.6%		
							2	819.2	34.1	5	92.4	3.9	47	2.6%		
2	Lighting,	4.00	2.50	15	60	0.2%	(Open	01012	0.112	6	92.4	3.9	47	2.6%	2.8%	
	controls						Office)			7	92.4	3.9	33	1.8%		
										8	92.4	3.9	33	1.8%		
										9	92.4	3.9	18	1.0%		
										10 11 F	66.2	2.8	40	1.6%		
								132.4	5.5	12 E	66.2	2.8	40	1.6%		
										1	40	1.7	41	1.0%		
										2	40	1.7	41	1.0%		
										3	92.4	3.9	47	2.6%		
										4	92.4	3.9	47	2.6%		
							2	000 0	22.6	5	92.4	3.9	18	1.0%		
,	Lighting,	1.00	2 /7	15	54	0.2%	3 (Onon	806.8	33.6	6	92.4	3.9	18	1.0%	2.00/	
3	controls	4.00	2.4/	15	54	0.2%	(Open Office)			/	46.2	1.9	18	0.5%	2.070	
							officey			9	94.6	3.9	31	1.7%		
										10	94.6	3.9	39	2.1%		
										11	75.6	3.2	57	2.6%		
								132 /	5.5	12 E	66.2	2.8	50	2.0%		
								132.4	5.5	13 E	66.2	2.8	50	2.0%		
										1	50.4	2.1	57	1.7%		
										2	94.6	3.9	43	2.3%		
										3	79.8 67.2	2.3	40	2.1%		
										- 5	50.4	2.0	30	0.9%		
										6	94.6	3.9	32	1.8%		
	Lighting						4	941	39.2	7	79.8	3.3	46	2.1%		
4	controls	4.00	2.84	15	114	0.4%	(Dining/			8	67.2	2.8	56	2.2%	2.8%	
	controlo						(Dining/ Break)	(Dining/ Break)			9	50.4	2.1	26	0.8%	
										10	75.6	3.2	38	1.7%		
										11	92.4	3.9	36	2.0%		
										12	46.Z	3.9	42	2.1%		
								10		14 F	71,4	3.0	-30	1.3%		
								138.6	5.8	15 E	67.2	2.8	58	2.3%		
										1	60	2.5	49	1.7%		
										2	80	3.3	34	1.6%		
										3	60	2.5	18	0.6%		
										4	87.2	3.6	26	1.3%		
F	Lighting,	1.00	1 70	15	00	0.2%	5	576.8	24.0	5	73.6	3.1	35	1.5%	2 0%	
2	controls,	4.00	1.79	15	98	0.3%	(Corridor)			6	80 ED 6	3.3	58	2.7%	3.0%	
	systems									/ 8	52.6	2.2	24 42	1 3%		
										9	30,8	1.3		1.0%		
								101 7	4.2	10 E	66.3	2.8	62	2.4%		
								101.7	4.2	11 E	35.4	1.5	78	1.5%		
6	Telecom devices, controls	4.00	-	15	-	-	6	Loc	ation and	loads base	d on low	voltage de	vice place	ment and wi	ring.	

 Table 33. Office DC Voltage Drop Calculation Spreadsheet

The spreadsheet shown in Table 33 shows the calculations conducted to ensure that the

voltage drop on the office floor DC circuits does not exceed 3%. The equation

$$V_{drop} = \frac{K(I)(L)(2)}{cmils}$$

K = resistance (ohms/cmil-ft) 11 for copper loaded to less than 50% ampacity 12 for copper loaded to greater than 50% ampacity I = load in amps L = one-way distance

was used to calculate the voltage drop.

Building Loads

The spreadsheet shown in Table 34 shows a numerical breakdown of the various building

loads, with AC and DC loads calculated separately. Energy savings, when quantifiable, are shown

as well.

	BL	JILDING ELE	CTRIC PC	OWER DEMA	ND ANI	D ENERGY SU	MMAR	1				
		DC Loa	ıds					AC Lo	ads			
Connected	d Load	Demand	Load	Expected	Load	Connected	d Load	Demand	Load	Expected	d Load	
				Interior Lig	hting							
123.0	kW	123.0	kW	112.6	kW	19.5	kW	19.5	kW	19.5	kW	
2.0	kW	2.0	kW	2.0	kW	1.0	kW	1.0	kW	1.0	kW	
31.3	kW	31.3	kW	22.4	kW	-	kW	-	kW	-	kW	
156.2	kW	156.2	kW	137.0	kW	20.5	kW	20.5	kW	20.5	kW	
		DC Energy	y Use	AC Energy	y Use	6.			Refer	ence or Assu	mptions	
Total Energy	/	454,273	kwh	62,282	kwh	Sav	ings Sol	irce	See LPI) analysis	-	
Energy Savii	ngs	95,825	kwh	10,647	kwh	Daylight har	vesting		See DA	analysis		
Energy Savii	ngs	17,922	kwh	-	kwh	5% efficiend	cy increa	ase for DC				
Expected Er	nergy	340,525	kwh	51,634	kwh							
	Recept	acles (Plug l	oad - no	t including d	esktop	s and monito	rs or lig	hting)				
-	kW	-	kW	-	kW	393	kW	328	kW	105	kW	
-	kW	-	kW	-	kW	20	kW	17	kW	6	kW	
-	kW	-	kW	-	kW	19	kW	14	kW	11	kW	
-	kW	-	kW	-	kW	432	kW	359	kW	121	kW	
		DC Energy	y Use	AC Energy	y Use	6.			Refer	ence or Assu	mptions	
Total Energy	/	-	kwh	447,275	kwh	Sav	ings Sol	irce	See off	ice power pl	an	
Enormy Couris	ogc	_	kwh	183 000	kwh		ntrole		بام مم؟	a load in sur	nort	
chergy Savii	iigs	-		105,000	K VVII	Flug Ioau co	1111013		see pro	ig ioau iii sup	ρυπ	
	Connected 123.0 2.0 31.3 156.2 Total Energy Energy Savin Energy Savin Expected Er - - - - - Total Energy Total Energy	Connected Load 123.0 kW 2.0 kW 31.3 kW 156.2 kW Total Energy Energy Savings Expected Energy Recept - kW - kW - kW - kW Total Energy	DC Loa Connected Load Demand 123.0 kW 123.0 2.0 kW 2.0 31.3 kW 31.3 156.2 kW 156.2 DC Energy 454,273 Energy Savings 95,825 Energy Savings 17,922 Expected Energy 340,525 Receptacles (Plug II) - - kW -	DC Loads Connected Load Demand Load 123.0 kW 123.0 123.0 kW 123.0 2.0 kW 2.0 31.3 kW 31.3 156.2 kW 156.2 DC Energy Use DC Energy Use Total Energy 454,273 Kwh 55,825 Energy Savings 17,922 Expected Energy 340,525 KW - kW <td>DC Loads Connected Load Demand Load Expected Interior Lig 123.0 kW 123.0 kW 112.6 2.0 kW 2.0 kW 2.0 31.3 kW 31.3 kW 22.4 156.2 kW 156.2 kW 137.0 DC Energy Use AC Energy Total Energy 454,273 kwh 62,282 Energy Savings 95,825 kwh 10,647 Energy Savings 17,922 kwh - Expected Energy 340,525 kwh 51,634 Receptacles (Plug load - not including d - kW - kW - - kW -</td> <td>DC Loads Connected Load Demand Load Expected Load Interior Lighting 123.0 kW 123.0 kW 112.6 kW 2.0 kW 2.0 kW 2.0 kW 31.3 kW 31.3 kW 2.4 kW 156.2 kW 156.2 kW 137.0 kW DC Energy Use AC Energy Use Total Energy 454,273 kwh 62,282 kwh Energy Savings 95,825 kwh 10,647 kwh Energy Savings 17,922 kwh - kwh Expected Energy 340,525 kwh 51,634 kwh Expected Energy 340,525 kwh - kW - kW - kW - kW - kW - kW - kW - kW - kW - kW -</td> <td>DC Loads Connected Load Demand Load Expected Load Connected Interior Lighting 123.0 kW 123.0 kW 112.6 kW 19.5 2.0 kW 2.0 kW 2.0 kW 100 31.3 kW 31.3 kW 22.4 kW - 156.2 kW 156.2 kW 137.0 kW 20.5 DC Energy Use AC Energy Use AC Energy Use Sav Total Energy 454,273 kwh 62,282 kwh Daylight har Energy Savings 17,922 kwh - kwh 5% efficience Expected Energy 340,525 kwh 51,634 kwh 5% Receptacles (Plug load - not including desktops and monito - kW - kW 20 - kW - kW 20 - kW - kW 393 - kW<</td> <td>DC Loads Connected Load Demand Load Expected Load Connected Load Interior Lighting 123.0 kW 123.0 kW 112.6 kW 19.5 kW 2.0 kW 2.0 kW 10.0 kW 2.0 kW 2.0 kW 1.0 kW 31.3 kW 20.2 kW - kW 156.2 kW 156.2 kW 137.0 kW 20.5 kW DC Energy Use AC Energy Use DC Energy Use Savings Sou Total Energy 454,273 kwh 62,282 kwh Daylight harvesting Energy Savings 17,922 kwh - kwh 5% efficiency increaters Expected Energy 340,525 kwh 51,634 kwh 5% - kW - kW 393 kW - kW -</td> <td>DC Loads AC Lo Connected Load Demand Load Expected Load Connected Load Demand Interior Lighting 123.0 kW 123.0 kW 112.6 kW 19.5 kW 19.5 2.0 kW 2.0 kW 1.0 kW 1.0 31.3 kW 31.3 kW 22.4 kW - kW - 156.2 kW 156.2 kW 137.0 kW 20.5 KW 20.5 DC Energy Use AC Energy Use Savings Source Total Energy 454,273 kwh 62,282 kwh Daylight harvesting Energy Savings 17,922 kwh - kwh 5% efficiency increase for DC Expected Energy 340,525 kwh 51,634 kwh 328 - kW - kW - kW 328 - kW - kW 404 20 kW</td> <td>DC Loads AC Loads Connected Load Demand Load Expected Load Connected Load Demand Load Interior Lighting 123.0 kW 123.0 kW 112.6 kW 19.5 kW 19.5 kW 123.0 kW 123.0 kW 123.0 kW 19.5 kW 19.5 kW 19.5 kW 10.0 kW 1.0 kW</td> <td>DC LoadsAC LoadsConnected LoadDemand LoadExpected LoadConnected LoadDemand LoadExpectedInterior Lighting123.0kW123.0kW112.6kW19.5kW19.5kW19.52.0kW2.0kW1.0kW1.0kW1.0kW1.031.3kW2.0kW2.0kW-kW-kW-156.2kW156.2kW137.0kW20.5kW20.5kW20.5DC Energy UseAC Energy UseAc Energy UseTotal Energy454,273kwh62,282kwhDaylight harvestingSee DA analysisEnergy Savings95,825kwh10,647kwhDaylight harvestingSee DA analysisEnergy Savings17,922kwh-kwh5% efficiency increase for DCExpected Energy340,525kwh51,634kwhCeptacles (Plug load - not including desktops and monitors or lighting)-kW-kW-kW10-kW-kW-kW10kW11-kW-kW-kW10kW11-kW-kW-kW121KW121DC Energy Use<th cols<="" td=""></th></td>	DC Loads Connected Load Demand Load Expected Interior Lig 123.0 kW 123.0 kW 112.6 2.0 kW 2.0 kW 2.0 31.3 kW 31.3 kW 22.4 156.2 kW 156.2 kW 137.0 DC Energy Use AC Energy Total Energy 454,273 kwh 62,282 Energy Savings 95,825 kwh 10,647 Energy Savings 17,922 kwh - Expected Energy 340,525 kwh 51,634 Receptacles (Plug load - not including d - kW - kW - - kW -	DC Loads Connected Load Demand Load Expected Load Interior Lighting 123.0 kW 123.0 kW 112.6 kW 2.0 kW 2.0 kW 2.0 kW 31.3 kW 31.3 kW 2.4 kW 156.2 kW 156.2 kW 137.0 kW DC Energy Use AC Energy Use Total Energy 454,273 kwh 62,282 kwh Energy Savings 95,825 kwh 10,647 kwh Energy Savings 17,922 kwh - kwh Expected Energy 340,525 kwh 51,634 kwh Expected Energy 340,525 kwh - kW - kW - kW - kW - kW - kW - kW - kW - kW - kW -	DC Loads Connected Load Demand Load Expected Load Connected Interior Lighting 123.0 kW 123.0 kW 112.6 kW 19.5 2.0 kW 2.0 kW 2.0 kW 100 31.3 kW 31.3 kW 22.4 kW - 156.2 kW 156.2 kW 137.0 kW 20.5 DC Energy Use AC Energy Use AC Energy Use Sav Total Energy 454,273 kwh 62,282 kwh Daylight har Energy Savings 17,922 kwh - kwh 5% efficience Expected Energy 340,525 kwh 51,634 kwh 5% Receptacles (Plug load - not including desktops and monito - kW - kW 20 - kW - kW 20 - kW - kW 393 - kW<	DC Loads Connected Load Demand Load Expected Load Connected Load Interior Lighting 123.0 kW 123.0 kW 112.6 kW 19.5 kW 2.0 kW 2.0 kW 10.0 kW 2.0 kW 2.0 kW 1.0 kW 31.3 kW 20.2 kW - kW 156.2 kW 156.2 kW 137.0 kW 20.5 kW DC Energy Use AC Energy Use DC Energy Use Savings Sou Total Energy 454,273 kwh 62,282 kwh Daylight harvesting Energy Savings 17,922 kwh - kwh 5% efficiency increaters Expected Energy 340,525 kwh 51,634 kwh 5% - kW - kW 393 kW - kW -	DC Loads AC Lo Connected Load Demand Load Expected Load Connected Load Demand Interior Lighting 123.0 kW 123.0 kW 112.6 kW 19.5 kW 19.5 2.0 kW 2.0 kW 1.0 kW 1.0 31.3 kW 31.3 kW 22.4 kW - kW - 156.2 kW 156.2 kW 137.0 kW 20.5 KW 20.5 DC Energy Use AC Energy Use Savings Source Total Energy 454,273 kwh 62,282 kwh Daylight harvesting Energy Savings 17,922 kwh - kwh 5% efficiency increase for DC Expected Energy 340,525 kwh 51,634 kwh 328 - kW - kW - kW 328 - kW - kW 404 20 kW	DC Loads AC Loads Connected Load Demand Load Expected Load Connected Load Demand Load Interior Lighting 123.0 kW 123.0 kW 112.6 kW 19.5 kW 19.5 kW 123.0 kW 123.0 kW 123.0 kW 19.5 kW 19.5 kW 19.5 kW 10.0 kW 1.0 kW	DC LoadsAC LoadsConnected LoadDemand LoadExpected LoadConnected LoadDemand LoadExpectedInterior Lighting123.0kW123.0kW112.6kW19.5kW19.5kW19.52.0kW2.0kW1.0kW1.0kW1.0kW1.031.3kW2.0kW2.0kW-kW-kW-156.2kW156.2kW137.0kW20.5kW20.5kW20.5DC Energy UseAC Energy UseAc Energy UseTotal Energy454,273kwh62,282kwhDaylight harvestingSee DA analysisEnergy Savings95,825kwh10,647kwhDaylight harvestingSee DA analysisEnergy Savings17,922kwh-kwh5% efficiency increase for DCExpected Energy340,525kwh51,634kwhCeptacles (Plug load - not including desktops and monitors or lighting)-kW-kW-kW10-kW-kW-kW10kW11-kW-kW-kW10kW11-kW-kW-kW121KW121DC Energy Use <th cols<="" td=""></th>	

Table 34. Building Load Summary

(continued on following page)

(from previous page)

			Computing	Loads (E	Desktops and	monite	ors on recept	acles)				
Rack Servers	35	kW	35	kW .	35	kW	-	kW .	-	kW	-	kW
Desktops & Monitors	-	kW	-	kW	-	kW	621	kW	621	kW	242	kW
Total	35	kW	35	kW	35	kW	621	kW	621	kW	242	kW
				مالدم		راادم				Pofor	anco or Assu	motions
	Total Energ	v	64 983	kwh	403 764	kwh	Savi	ings Sou	urce	See cor	mouting now	/er
	Energy Savi	ngs	3 249	kwh		kwh	5% efficienc	v incre	ase for DC	500 001	inputing por	
	Expected E	nergy	61,734	kwh	403.764	kwh	570 efficient	y more		1		
			/		,							
				М	echanical Eq	uipmer	nt					
Office	15	kW	15	kW	15	kW	-	kW	-	kW	-	kW
Below Grade	36.5	kW	36.5	kW	36.5	kW	-	kW	-	kW	-	kW
Mechanical Platform	37.4	kW	37.4	kW	37.4	kW	-	kW	-	kW	-	kW
Penthouse	68.3	kW	45.3	kW	45.3	kW	-	kW	-	kW	-	kW
Rooftop	95	kW	95	kW	95	kW	-	kW	-	kW	-	kW
Total	252.2	kW	229.2	kW	229.2	kW		kW		kW		kW
			DC Energy	v Use	AC Energy	/ Use				Refere	ence or Assu	motions
	Total Energ	v	295.769	kwh	-	kwh	Savi	ings Sou	urce	See me	chanical loa	ds
	Energy Savi	, ngs	14.788	kwh	-	kwh	5% efficiend	v incre	ase			
	Expected E	nergy	280,980	kwh	-	kwh		/				
		0/	,									
					System	s						
Fire Alarm	-	kW	-	kW	-	kW	37	kW	37	kW	9	kW
Telecom/Data	130	kW	130	kW	130	kW	-	kW	-	kW	-	kW
Total	130	kW	130	kW	130	kW	37	kW	37	kW	9	kW
			DC Energy	v Use	AC Energy	/ Use				Refere	ence or Assu	mptions
	Total Energ	v	39.000	, sse kwh	78.840	kwh	Savi	ings Sou	urce			
	Energy Savi	, ngs	1,950	kwh	-	kwh	5% efficiend	cy increa	ase			
	Expected E	nergy	37,050	kwh	78,840	kwh		,				
					Miscellane	eous						
Electrochromic glass	3	kW	3	kW	3	kW	-	kW	-	kW	-	kW
Total	3	kW	3	kW	3	kW		kW		kW		kW
		1	DC Energy	y Use	AC Energy	/ Use				Refere	ence or Assu	mptions
	Total Energ	y	3,000	kwh	-	kwh	Savi	ings Sou	urce			•
	Energy Savi	ngs	150	kwh	-	kwh	5% efficiend	cy increa	ase			
	Expected E	nergy	2,850	kwh	-	kwh						
					Electric	Power	Demand Sum	mary				
			DC Loa	ds					AC Lo	ads		
	Connecte	d Load	Demand	Load	Expected	Load	Connected	Load	Demand	Load	Expecte	d Load
	576.4	kW	553.4	kW	534.2	kW	1,110.1	kW	1,037.5	kW	392.4	kW
									-			
			Ex	pected I	Energy Use							
	-	DC Er	nergy	I		AC E	nergy					
	Before Savi	ngs	857,024	kwh	Before Savi	ngs	992,161	kwh	-			
	Atter Savin	igs	/23,139	ĸwh	Atter Savin	gs	/98,514	кwh	J			
			C	votivo F	norm Estim	ato			1			
		DCF	Conser	vative	inergy Estimation		norm		-			
	1		annual	kwb			annual	kwb				
	I, Fuel cell ar	nalvsis m	annual anducted as	Suming	additional D	000,000 C load a	s a conservat	ive	1			
	estimate in	the eve	nt that proje	ected DC	Cenergy savi	ngs are	lower than					
	expected	Servero	r mechanica	l expan	sion may resi	ultinla	rger DC ener	gy use				
					,		0	.,	4			

Appendix G

Fuel Cell

After considering several fuel cell options, three 400 kW units were selected to support

the expected 1,000 kW building load without under or over sizing.

						FUEL	CELL AN	ALYSIS						
Fuel Cell	Max Out	tput	Output Vo	oltage	Electrical Efficiency	Natural Consump	Gas otion	Heat f	or Reco	very		CO ₂ Emissio	ins	Space Required (Dimen. & Area)
ClearEdge Model 400 PureCell	400	kW	480 380	VAC VDC	42% 47%	3,630,000	Btu/h	1,550,000	Btu/h	at 140°F	1059 497	lb/MWh lb/MWh	no recovery w/ recovery	27'4" x 8'4" x 10'
Expected AC Energy Expected DC Energy	800,000 1,000,000	kwh kwh	Annually Annually											
					Nat	ural Gas Fue	I Usage							
Fuel Cell	Electrical E Use	nergy	Hours of	Use	Total E Consur [using el efficie	nergy nption ectrical ency]	Cas (Consumption in	kBtu	Gas Consu The	mption in rms	Month	ly Therms	
ClearEdge AC	800000	kwh	2000	hr	1904762	kwh		6499048	kBtu	64990	therms	5416	therms	
ClearEdge DC1	500000	kwh	1250	hr	1063830	kwh		3629787	kBtu	36298	therms	3025	therms	
ClearEdge DC2	500000	kwh	1250	hr	1063830	kwh		3629787	kBtu	36298	therms	3025	therms	
Total	1800000	kwh	4500	hr	4032421	kwh		13,758,622	kBtu	137586	therms	11466	therms	
		Heat for	Recovery		•					Prir	mary Fuel Co	mparison		
	Heat Reco	overy	Actual He	at to	Annual Ener	rgy Used in		Energy Sou	irce	Annual Pri	mary Fuel		Assumpti	ons
	from Fue	l Cell	Mechanica	al Equ.	Recover	ry Heat				Energy Cor	sumption			
ClearEdge Model 400	6975000	kBtu	4185000	kBtu	1226553	kwh	J	Grid Natural Ga	as with	4,480,468	kwh	Natural gas	tranmission r	esults in 10%
	•						1	Fuel Cells				losses from	source to site	
	100C200	rbon Fo		lum.	Annually no			Grid Electric		5,806,452	kwh	Electric grid	d is 33% efficien	nt from source to
ClearEdge Model 400	1906200	ID Ib	804037	кg ka	Annually, no	recovery		Souings		1 225 002	kuub	site after ge	eneration and ti	anmission
	694000	ID	403765	ĸg	Annually, wi	unrecovery	1	Drin	non/Eu	al Utilization	Comparison			
							1		laryru	erotilization	companson			
		Cost	Analysis					Energy Source	En	ergy Use	Energy Cor	sumption		
Summer \$/Month	Winter \$/N	Nonth	Flat Ś		Total Ś				Total R	eauired	4.480.468	kwh		
	Co	ost using	g natural gas						Electric	city	1,800,000	kwh		
\$9,239.83	\$9	,815.10	\$1,808.64		\$116,138.22	Annually		Fuel Cell	Recove	ery Heat	343,563	kwh		
	Cos	t using g	rid electricit	Y			1		Percen	t of total	48%	kwh		
\$35,259.50	\$22	2,458.50	-		\$346,308.00	Annually	1		Total R	equired	5,806,452	kwh		
Monetary Savin	gs from usir	g Fuel C	Cells		\$230,169.78	Annually		Electric Grid	Electric	city	1,800,000	kwh		
									Percen	t of Total	31%	kwh		

Table 35. Fuel Cell Analysis Summary

Table 35 analyzes the impact of using fuel cells to produce enough energy to meet the entirety of the building's electrical loads. Each fuel cell has an electrical output of 400 kW, making them capable of supplying 800 kW of DC power and 400 kW of AC power simultaneously to cover the expected 540 kW DC load and 393 kW AC load. The connected AC load (1,110 kW) exceeds the capacity of the AC fuel cell, but the fuel cell was sized to the

expected load. The connected load includes the maximum receptacle loads, even though this capacity will not be reached.

The expected energy is calculated from this value using assumptions about when equipment will be used throughout the year. It also accounts for potential energy savings. The expected natural gas consumption was calculated using the expected AC and DC energy usage and the electrical efficiency of the fuel cells. It is important to note that the increase in efficiency of the DC fuel cells comes as a result of the inverter being eliminated from the system. On average, industrial inverters operating at partial load will have efficiency at or below 95%.[4] Heat can also be recovered from the process, and mechanical simulations anticipate that it will meet the heating load 87% of the time. Extra heat is exhausted through a duct to the rooftop along with the carbon dioxide that is produced as a byproduct. From a maintenance standpoint, the fuel cell stacks will require replacement after 10 years of use.

Due to the low price of PG&E's natural gas compared to its electric grid, which continues to increase rates, using the fuel cells to supply the building's electrical loads will save approximately \$230,000 annually. The capital cost of the fuel cells is also low, as the self-generation incentives shown in Figure 58 from the federal government and Figure 68 (below) from PG&E provide over 80% of the initial cost.

Self-Generation Incentive Program (SGIP)

The 2014 incentive levels are as follows:

\$33.4 million per year in available incentives	75 percent renewable ar emerging/25 percent nonrenewable	nd
Incentive levels	Technology	Incentive (\$/watt)
Renewable, waste heat capture technologies	Wind turbines	\$1.13/W
	Waste heat to power	\$1.13/W
	Pressure reduction turbine	\$1.13/W
	Renewable microturbine (on-site or directed biogas)	\$2.08/W*
	Renewable internal combustion engine (on-site or directed biogas)	\$2.08/W*
	Renewable gas turbine (on- site or directed biogas)	\$2.08/W*
	Renewable fuel cells (on- site or directed biogas)	\$3.45/W*
Emerging technologies	Advanced Energy Storage (AES)	\$1.62/W
	Fuel cells: combined heat and power (CHP) or electric	\$1.83/W

Figure 68. Fuel Cell PG&E Incentives

Most importantly, as 350 Mission aims to be net-zero, the comparison of primary fuel usage between onsite generation with the fuel cells and the electric grid is shown in the red box in Table 35. The natural gas fuel cells save over 100,000 kWh annually and lead to a 15% efficiency increase.

Appendix H

Server Room Sizing

VMware is an industry leader in cloud and virtualization software. The following method for sizing 350 Mission's server room is derived from a VMware publication entitled "Server and Storage Sizing Guide for Windows 7 Desktops in a Virtual Desktop Infrastructure." The results were then verified with actual rack server technical specification sheets and server sizing guides from Dell, HP, and IBM. The comparison found the results of this method to be an accurate estimate of server sizing.

 $(Virtual Machines per Server) = \frac{Cores Available on Server}{vCPUs Needed per Virtual Machine} x (Overcommit Ratio of vCPUs per pCPU)$

pCPU = physical central processing unit vCPU = virtual central processing unit

- I doite e of Itequit		
USER/WORKER	APPLICATIONS	VIRTUAL MACHINE
TYPE	(OPEN SIMULTANEOUSLY)	CONFIGURATION
Task-based worker	Limited	1 virtual CPU
(light)	(1–5 applications, light use)	1GB memory
Knowledge worker	Standard office	2 virtual CPUs
(medium)	(1-5 applications, regular use)	2GB memory
Power user	Compute-intensive	2 virtual CPUs
(heavy)	(5+ applications, regular use)	4GB memory
Power user plus	Compute-intensive	2+ virtual CPUs
(heavy)	(5+ applications, intense use)	4GB memory

Table 36. Required Processing Power for Various Applications [14]

It is assumed that most employees would not require more intensive power requirements than the category highlighted in the table above. This is likely a conservative estimate that will result in more processing power than will be required, but it is not excessive to the point that processing power is being wasted. To accommodate users with heavy processing demands, 12 non-virtual desktops are planned for each office floor.

Conservative overcommit ratio = 6:1 (vCPUs:pCPU)

Rack servers are available in countless configurations with various packages of processing cores, internal memory, storage, and other options. For these calculations, a server with 24 available cores was chosen, as it offered an adequate balance between performance, power consumption, and cost (based on Dell, HP, and IBM servers). The Eltek Flatpack2 DC/DC converter for data center applications operates at an industry-leading 98% efficiency and is specified for the 350 Mission server room. IBM and HP manufacture 380VDC server power supplies as well.

Virtual Machines per Server
$$=$$
 $\frac{24}{2}x$ 6 $=$ 72 Virtual Machines per Server

Based on this calculation, a server with 24 cores can serve approximately 70 thin client virtual desktops. Therefore, it would require two servers per office floor to accommodate the necessary computing capacity. Again, this value is on the conservative side, as these servers will accommodate about 140 virtual desktops, which exceeds the demand of each office floor.

On average, with the technology available, a server of this capacity consumes a maximum of 700 Watts. The resulting reduction in demand power using the server room arrangement compared to full-capacity, non-virtual desktops is summarized in Table 37.

Average rack server	Max Power [W]	700	Avg. Power [W]	600	Idle Power [W]	420	Sleep Power [W]	200	Off Power [W]	5
Average thin client	Max Power [W]	30	Avg. Power [W]	15	Idle Power [W]	10	Sleep Power [W]	4	Off Power [W]	2
Average full-capacity desktop	Max Power [W]	175	Avg. Power [W]	120	Idle Power [W]	85	Sleep Power [W]	5	Off Power [W]	3
Average LED or LCD monitor	Max Power [W]	30	Avg. Power [W]	30	Idle Power [W]	20	Sleep Power [W]	2	Off Power [W]	1
Maximum Power Per Office Floor										
Computing Method	Rack Servers	DC Power [kW]	Thin Client Desktops	AC Power [kW]	Full-Capacity Desktops	AC Power [kW]	Monitors (Backlit LED)	AC Power [kW]	Total Maximum	Power
Virtual Computing	2	1.4	120	3.6	12	2.1	132	4.0	11.1 k	W
Traditional Computing	-	-	-	-	132	23.1	132	4.0	27.1 k	W
			Maximum Po	ower for th	ne Entire Buildin	g				
Virtual Computing	50	35	3000	90	300	52.5	3300	99	276.5 k	W
Traditional Computing	-	-	-	-	3300	577.5	3300	99	676.5 k	W
Computing Maximum Pov	Computing Maximum Power Demand Summary Note about Computing Power Demand Analysis									
Virtual Computing Connected				The AC co	omputer loads (e	every load	except the server	s) is suppl	ied by receptacle	s and
Power	276.5	kW		are included in the receptacle table and load summaries. This analysis was completed						
Traditional Computing				for two reasons, the first being a method of quantifying estimated energy savings over						
Connected Power	676.5	kW		traditiona	raditional computing methods. The second was to evaluate whether the computing					
Connected Power Reduction	400	kW		loads cou	could be met by the fuel cells when using actual loads, and not receptacles loads					
Connected Power Reduction	59%	-		that cons	ervatively overe	stimate p	ower demand.			
Estimated Energy Usage				1	Energy Assumptions					
Virtual Computing Connected					Assume an aver	rage of 7 h	ours of active use,	1.5 hours	of idle use, 1 hou	urs of
Power		kwh per		kwh sleep use, and 14.5 hours of off use per workday. 'Off' status on weeken					ends	
- ower	1865.4	workday	476,872	annually	/ and holidays. Assume 255 annual workdays.					
Traditional Computing					Assume an average of 7 hours of active use, 1.5 hours of idle use, 1 hours of					
Connected Power		kwh per		kwh	sleep use, and 14.5 hours of off use per workday. 'Off' status on weekends			ends		
connected rower	4199.3	workday	1,072,327	annually	and holidays. A	ssume 25	5 annual workdays			
		kwh per		kwh			-			
Connected Power Reduction	2333.9	workday	595,454	annually						
		kwh per		kwh			_			
Connected Power Reduction	56%	workday	56%	annually						

Table 37.	Computing Pov	ver Demand (Comparison –	Virtual vs.	Traditional	Computing	5

As shown in Figure 69, at each floor, the data and telecom services are supplied through a fiber patch panel and patch panel. Six hardwired access panels provide WiFi, and open office workstations are equipped with a voice/data outlet for voice over internet protocol (VoIP) phones. Conference rooms have a TV outlet and voice/data outlet. TV outlets/TVs are also provided near the elevator lobby to make occupants aware of their monthly energy usage.



Figure 69. Data System Schematic

Appendix I

Seismic Design

Lobby Earthquake Analysis

California Department of General Services · Division of the State Architect · Interpretation of Regulations Document

PEND/	٩NT	MOL	JNT	ED	
LIGHT	FIX	TUR	ES		



Revised 11-03-10

Issued 06-22-09

References: California Code of Regulations (CCR), Title 24 Part 2, California Building Code (CBC) 2001 CBC, Section 2501A.5.2 2007 CBC, Section 1614A1.12.

2010 CBC, Section 1615A1.16, 1615.10.13* ASCE 7 Sections 13.6.1 and 13.2.3

Discipline: Structural

This Interpretation of Regulations (IR) is intended for use by the Division of the State Architect (DSA) staff, and as a resource for design professionals, to promote more uniform statewide criteria for plan review and construction inspection of projects within the jurisdiction of DSA which includes State of California public elementary and secondary schools (grades K-12), community colleges and state-owned or state-leased essential services buildings. This IR indicates an acceptable method for achieving compliance with applicable codes and regulations, although other methods proposed by design professionals may be considered by DSA.

This IR is reviewed on a regular basis and is subject to revision at any time. Please check the DSA web site for currently effective IRs. Only IRs listed in the document at <u>http://www.dgs.ca.gov/dsa/Resources/IRManual.aspx</u> at the time of plan submittal to DSA are considered applicable.

*Indicates alternative 2010 CBC sections that may be used by community colleges, per 2010 CBC Section 1.9.2.2.

Purpose: The purpose of this Interpretation of Regulations (IR) is to set forth an acceptable method for support of pendant mounted light fixtures.

General: Pendant mounted light fixtures that are free to swing in the lateral direction shall be detailed and installed so that they can swing at least 45 degrees from the vertical in any direction without contacting an obstruction. Adjacent fixtures shall be separated by a distance equal to at least one and one half times the length of the pendant.

Exception: When it can be demonstrated by rational analysis that fixtures will swing less than 45 degrees in the maximum credible earthquake, fixture location and spacing may be based on such analysis.

1. SAFETY CABLES: Fixtures that are supported by cables shall have cables (including cable connections and supports) designed to support a load of at least 1.4 times the weight of the fixture acting simultaneously in the vertical and horizontal direction and applied at the point of lateral support. Fixtures supported by hollow rods, or other support mechanisms shall be provided with a "safety cable" attached directly to the fixture and directly to competent supporting structure above. The safety cable, its connections, and supports shall be designed to support a load of at least 1.4 times the weight of the fixture acting simultaneously in the vertical and horizontal direction and applied at the point of lateral support.

Figure 70. DGS Regulations for Pendant Mounted Luminaires in Earthquake Areas

The document shown in Figure 70, created by the California Department of General

Services (DGS), outlines the requirements for the use of pendant mounted light fixtures in

earthquake-prone areas. The sections outlined in red are those that specifically relate to 350 Mission.

The fixture support cables and connections to the ceiling are designed to carry 1.4 times the weight of the fixtures they are supporting. Connections allow movement in all directions, as required by both the California DGS and the Federal Emergency Management Agency (FEMA).



Figure 71. Isometric and Plan Views of Lobby with Luminaire Swing Areas Defined Figure 71 shows various views of the model that aided in the lobby design. The blue planes define the interference space for each. Fixtures can swing 45⁰ in any direction without the risk of colliding with another luminaire or its support cables. The edges of the swing areas are lined in red to improve visibility.

These figures prove that the lobby lighting design follows the requirements set by the California DGS. FEMA has less explicit instructions for design, simply stating that "care must be taken to avoid seismic interactions with adjacent objects when the suspended component swings." This lighting layout satisfies all of the required earthquake safety measures.

BIBLIOGRAPHY

Websites

- [1] "Commercial Flat Roof Grid-Tie Solar Panel Systems." Solar Electric Supply, Inc.. http://www.solarelectricsupply.com/commercial-solar-systems/flat-roof
- [2] "EMerge Alliance." EMerge Alliance. http://www.emergealliance.org/
- [3] "Federal Business Energy Investment Tax Credit (ITC)." DSIRE USA. http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=US02F
- [4] "List of Eligible Inverters per SB1 Guidelines." Go Solar California. http://www.gosolarcalifornia.ca.gov/equipment/inverters.php
- [5] "Mapping California's Seafloor." California Ocean Protection Council. http://www.opc.ca.gov/
- [6] "Power Supply System." Taipei 101. http://www2.taipei-101.com.tw/en/Tower/buildind_07-1.html
- [7] San Francisco Department of the Environment and CH2M HILL. "San Francisco Urban Wind Map." San Francisco Energy Map. http://www.sfenergymap.org/
- [8] "Self-Generation Incentive Program (SGIP)." PG&E. http://www.pge.com/en/mybusiness/save/solar/sgip.page
- [9] "Supercritical Sanitation Systems: Neighborhood-Scale Sewage Treatment." Duke University, Pratt School of Engineering. http://sanitation.pratt.duke.edu/home

Documents/Books

- [10] "A Practical Guide to Fire Alarm Systems." Central Station Alarm Association. http://www.csaaintl.org/2011FireAlarmBookONLINE.pdf
- [11] DiLaura, David, Kevin Houser, Richard Mistrick, and Gary Steffy. The Lighting Handbook: Reference and Application. 10th ed. New York, NY: Illuminating Engineering Society, 2011.
- [12] "LEED 2009 for New Construction and Major Renovations Rating System." U.S. Green Building Council. http://www.usgbc.org/Docs/Archive/General/Docs5546.pdf

- [13] "Plug Load Circuit Controls: 2013 California Building Energy Efficiency Standards ." California Utilities Statewide Codes and Standards Team. http://www.energy.ca.gov/title24/2013standards/prerulemaking/documents/current/Repor ts/Nonresidential/Lighting_Controls_Bldg_Power/2013_CASE_NR_Plug_Load_Circuit_ Control_Oct_2011.pdf
- [14] "Server and Storage Sizing Guide for Windows 7 Desktops in a Virtual Desktop Infrastructure." VMware. https://www.vmware.com/files/pdf/view/Server-Storage-Sizing-Guide-Windows-7-TN.pdf
- [15] Shalva, Anthony. "The ABC's of Fire Alarm Systems." IMSA Journal, May/June (2009): 42-45.
- [16] "Total installed cost comparison study of motorized shading systems." Lutron Electronics, Inc.. http://www.lutron.com/TechnicalDocumentLibrary/367-1548.pdf

Programs

PROGRAM	USES	FILE TYPE	INPUT FROM	OUTPUT TO
AGI32	Lighting Calculations	.agi	AutoCAD	N/A
AUTOCAD	3D Modeling 2D Sections and Details	.dwg & .dxf	Revit	AGI32, Rhino
DAYSIM	Daylight Calculations	.hea	AutoCAD	Excel
DIVA FOR RHINO	Daylight Calculations Radiation Maps	.3dm	AutoCAD	Excel
EXCEL	Data Analysis Load Calculations	.xls	Daysim, DIVA	
РНОТОЅНОР	Graphic Development	.psd	Revit, AGI	
PV WATTS	Solar Panel Analysis			
REVIT	Floor Plans, Model Development	.rvt		AutoCAD

ACADEMIC VITA

Lara Kaiserian larakaiserian@gmail.com

Education

The Pennsylvania State University Schreyer Honors College, University Park, PA Master and Bachelor of Architectural Engineering, Lighting/Electrical Option Minor: Architectural Studies EIT upon graduation (Pennsylvania FE Exam, April 2013)

Professional Experience

EwingCole (Philadelphia, PA) Lighting/Electrical Engineering Intern Project team member for this fully-integrated architecture, engineering, interior design, and planning firm in the design of a net-zero building; used AutoCAD 2010 MEP, Revit 2012

- Completed daylighting (Daysim) and lighting (AGI 32) calculations
- Selected luminaires and developed layouts, circuited fixtures, created schedule
- Prepared lighting and electrical drawings including floor plans, installation and layout details, and equipment and panel schedules (AutoCAD 2010 MEP, Revit 2012)
- Designed spreadsheets for automated lighting calculations (Microsoft Excel)

Study Abroad

Completed two seven-week Architectural Engineering study abroad sessions China – Shanghai, Beijing, Hong Kong

- Studied the rapid development of modern Chinese cities, toured Chinese historical sites
- Attended 10 day International Construction seminar at Tsinghua University, Beijing
- Design and Urban Planning Museum for Hong Kong; created physical and Revit models

Italy – based in Rome, organized travel to Florence, Venice, Naples, Verona, Como, Milan

- Used historic maps and architectural drawings combined with physical evidence to trace the evolution of Rome and Roman architecture from ancient times to modern day
- Designed an art museum for Rome, combining cultural traditions and contemporary ideas

Activities/Honors

Penn State Club Water Polo Captain 2012-14, , Webmaster 2010-14, Vice President 2013, Treasurer 2010-12 Collegiate Water Polo Association All-American 2013, All-Conference 2011, 2012, 2013 Academic All-American 2010, 2011, 2012, 2013
Penn State Homecoming Merchandise Director 2012, Merchandise Captain 2010, 2011
Engineering Ambassadors 2012-13
IFC/Panhellenic Dance Marathon (THON)

Captain 2014, Committee Member 2010-13